

**PROPERTY MAINTENANCE CODE
OF
MANHEIM TOWNSHIP,
LANCASTER COUNTY, PENNSYLVANIA**

ALL RIGHTS RESERVED. This is a copyrighted work owned by Manheim Township, Lancaster County, Pennsylvania. Without advance written permission from the copyright owner, no part of this book may be reproduced, distributed or transmitted in any form or by any means.

Portions of this publication reproduce text, tables and figures from the *2015 International Property Maintenance Code*, copyrighted material which is proprietary to and owned by the International Code Council, Inc., Washington, D.C. This publication is reproduced with permission. The acronym "ICC" and the ICC logo are trademarks and service marks of ICC. ALL RIGHTS RESERVE

Table of Contents

CHAPTER 1 SCOPE AND ADMINISTRATION.....	1
PART 1 — SCOPE AND APPLICATION	1
SECTION 101 GENERAL	1
101.1 Title.	1
101.2 Scope.....	1
101.3 Intent.....	1
101.4 Severability.....	1
SECTION 102 APPLICABILITY	1
102.1 General.....	1
102.2 Maintenance.	1
102.3 Application of other codes.....	2
102.4 Existing remedies.	2
102.5 Workmanship.....	2
102.6 Historic buildings.....	2
102.7 Referenced codes and standards.....	2
102.7.1 Conflicts.....	2
102.7.2 Provisions in referenced codes and standards.	2
102.8 Requirements not covered by code.....	2
102.9 Application of references.....	3
102.10 Other laws.....	3
PART 2 — ADMINISTRATION AND ENFORCEMENT	3
SECTION 103 DEPARTMENT OF PROPERTY MAINTENANCE INSPECTION	3
103.1 General.....	3
103.2 Liability.....	3
103.2.1 Legal defense.	3
103.3 Fees.....	3
SECTION 104 DUTIES AND POWERS OF THE CODE OFFICIAL	3
104.1 General.....	3
104.2 Inspections.....	4
104.3 Right of entry.....	4

104.3.1 Refusal of Entry.	4
104.3.2 Right of Entry by Owner.	5
104.3.3 Notification to Tenants.....	5
104.4 Identification.....	5
104.5 Notices and orders.....	5
104.6 Department records.....	5
SECTION 105 APPROVAL.....	5
105.1 Modifications.	5
105.2 Alternative materials, methods and equipment.....	5
105.3 Required testing.....	6
105.3.1 Test methods.	6
105.3.2 Test reports.....	6
105.4 Used material and equipment.	6
105.5 Approved materials and equipment.....	6
105.6 Research reports.....	6
SECTION 106 VIOLATIONS.....	6
106.1 Unlawful acts.....	6
106.2 Notice of violation.....	6
106.3 Prosecution of violation.....	6
106.4 Violation penalties.	7
106.5 Abatement of violation.	7
106.6 Extensions.....	7
SECTION 107 NOTICES AND ORDERS.....	7
107.1 Notice to person responsible.....	7
107.2 Form.....	7
107.3 Method of service.....	8
107.4 Unauthorized tampering.....	8
107.5 Penalties.....	8
107.6 Transfer of ownership.....	8
SECTION 108 UNSAFE STRUCTURES, EQUIPMENT AND PREMISES.....	8
108.1 General.....	8
108.1.1 Unsafe structures.....	9

108.1.2 Unsafe equipment.....	9
108.1.3 Structure unfit for human occupancy.....	9
108.1.4 Unlawful structure.	9
108.1.5 Dangerous structure or premises.	9
108.2 Closing of vacant structures.....	11
108.2.1 Authority to disconnect service utilities.	11
108.3 Notice.....	11
108.4 Placarding.....	12
108.4.1 Placard removal.	12
108.5 Prohibited occupancy.	12
108.6 Abatement methods.....	12
108.7 Record.....	12
SECTION 109 EMERGENCY MEASURES	12
109.1 Imminent danger.	12
109.2 Temporary safeguards.....	13
109.3 Closing streets.....	13
109.4 Emergency repairs.	13
109.5 Costs of emergency repairs.....	13
109.6 Hearing.....	13
SECTION 110 DEMOLITION	13
110.1 General.....	13
110.2 Notices and orders.....	14
110.3 Failure to comply.	14
110.4 Salvage materials.	14
SECTION 111 MEANS OF APPEAL.....	14
111.1 Application for appeal.....	14
111.2 Notice of meeting.	14
111.3 Open hearing.	14
111.3.1 Procedure.....	14
111.4 Postponed hearing.....	14
111.5 Board decision.....	15
111.5.1 Records and copies.	15

111.5.2 Administration	15
111.6 Court review.....	15
111.7 Stays of enforcement.....	15
SECTION 112 STOP WORK ORDER.....	15
112.1 Authority.....	15
112.2 Issuance.....	15
112.3 Emergencies.....	15
112.4 Failure to comply.....	15
CHAPTER 2 DEFINITIONS.....	16
SECTION 201 GENERAL	16
201.1 Scope.....	16
201.2 Interchangeability.....	16
201.3 Terms defined in other codes.....	16
201.4 Terms not defined.....	16
201.5 Parts.....	16
SECTION 202 GENERAL DEFINITIONS.....	16
ANCHORED.....	16
APPROVED.....	16
BASEMENT.....	16
BATHROOM.....	16
BEDROOM.....	16
CODE OFFICIAL.....	16
CONDEMN.....	17
COST OF SUCH DEMOLITION OR EMERGENCY REPAIRS.....	17
DETACHED.....	17
DETERIORATION.....	17
DWELLING UNIT.....	17
EASEMENT.....	17
EQUIPMENT SUPPORT.....	17
EXTERIOR PROPERTY.....	17
GARBAGE.....	17
GUARD.....	17

HABITABLE SPACE.	17
HEATING FACILITY.	17
HISTORIC BUILDING.	17
HOUSEKEEPING UNIT.	18
IMMINENT DANGER.	18
INFESTATION.	18
INOPERABLE MOTOR VEHICLE.	18
LABELED.	18
LAVATORY.	17
LET FOR OCCUPANCY or LET.	18
NEGLECT.	18
OCCUPANCY.	18
OCCUPANT.	18
OPENABLE AREA.	18
OPERATOR.	18
OWNER.	18
PERSON.	19
PEST ELIMINATION.	19
PLUMBING.	17
PREMISES.	19
PUBLIC WAY.	19
ROOMING HOUSE.	19
ROOMING UNIT.	19
RUBBISH.	19
SLEEPING UNIT.	19
STRICT LIABILITY OFFENSE.	19
STRUCTURE.	19
TENANT.	19
TOILET ROOM.	19
ULTIMATE DEFORMATION.	19
VENTILATION.	20
WATER CLOSET.	17

WORKMANLIKE.....	20
YARD.....	20
CHAPTER 3 GENERAL REQUIREMENTS	21
SECTION 301 GENERAL	21
301.1 Scope.....	21
301.2 Responsibility.....	21
301.3 Vacant structures and land.....	21
301.3.1 Exterior Conditions.....	21
SECTION 302 EXTERIOR PROPERTY AREAS	21
302.1 Sanitation.....	21
302.2 Grading and drainage.....	21
302.3 Sidewalks and driveways.....	21
302.4 Weeds.....	22
302.5 Rodent harborage.....	22
302.6 Exhaust vents.....	22
302.7 Accessory structures.....	22
302.8 Motor vehicles.....	22
302.9 Defacement of property.....	22
302.10 Trees, bushes and shrubs.....	22
SECTION 303 SWIMMING POOLS, SPAS AND HOT TUBS.....	23
303.1 Swimming pools.....	23
303.2 Enclosures.....	23
SECTION 304 EXTERIOR STRUCTURE	23
304.1 General.....	23
304.1.1 Unsafe conditions.....	23
304.2 Protective treatment.....	24
304.3 Premises identification.....	25
304.4 Structural members.....	25
304.5 Foundation walls.....	25
304.6 Exterior walls.....	25
304.7 Roofs and drainage.....	25
304.8 Decorative features.....	25

304.9 Overhang extensions.	25
304.10 Stairways, decks, porches and balconies.	26
304.11 Chimneys and towers.....	26
304.12 Handrails and guards.	26
304.13 Window, skylight and door frames.	26
304.13.1 Glazing.....	26
304.13.2 Openable windows.	26
304.14 Insect screens.....	26
304.15 Doors.....	26
304.16 Basement hatchways.	27
304.17 Guards for basement windows.	27
304.18 Building security.....	27
304.18.1 Doors.	27
304.18.2 Windows.	27
304.18.3 Basement hatchways.	27
304.19 Gates.	27
SECTION 305 INTERIOR STRUCTURE.....	27
305.1 General.....	27
305.1.1 Unsafe conditions.	27
305.2 Structural members.	28
305.3 Interior surfaces.	28
305.4 Stairs and walking surfaces.	28
305.5 Handrails and guards.	28
305.6 Interior doors.	28
SECTION 306 INTENTIONALLY LEFT BLANK.....	29
SECTION 307 HANDRAILS AND GUARDRAILS.....	29
307.1 General.....	29
SECTION 308 RUBBISH AND GARBAGE	29
308.1 Accumulation of rubbish or garbage.	29
308.2 Disposal of rubbish.....	29
308.2.1 Rubbish storage facilities.	29
308.2.2 Refrigerators.	29

308.3 Disposal of garbage.....	29
308.3.1 Garbage facilities.....	29
308.3.2 Containers.....	30
308.3.3 Storage, collection and removal.....	30
308.3.4 Recyclables.....	30
308.4 Solid Waste and Recyclable Ordinance.....	30
SECTION 309 PEST ELIMINATION.....	30
309.1 Infestation.....	30
309.2 Owner.....	30
309.3 Single occupant.....	30
309.4 Multiple occupancy.....	30
309.5 Occupant.....	30
SECTION 310 KITCHEN FACILITIES.....	30
310.1 Kitchen stove.....	31
310.2 Kitchen sink.....	30
310.3 Refrigerator.....	30
310.4 Counters and cabinets.....	30
CHAPTER 4 LIGHT, VENTILATION AND OCCUPANCY LIMITATIONS.....	32
SECTION 401 GENERAL.....	32
401.1 Scope.....	32
401.2 Responsibility.....	32
401.3 Alternative devices.....	32
SECTION 402 LIGHT.....	32
402.1 Habitable spaces.....	32
402.2 Common halls and stairways.....	32
402.3 Other spaces.....	33
SECTION 403 VENTILATION.....	33
403.1 Habitable spaces.....	33
403.2 Bathrooms and toilet rooms.....	33
403.3 Cooking facilities.....	33
403.4 Process ventilation.....	33
403.5 Clothes dryer exhaust.....	33

SECTION 404 OCCUPANCY LIMITATIONS.....	34
404.1 Privacy.....	34
404.2 Minimum room widths.....	34
404.3 Minimum ceiling heights.....	34
404.4 Bedroom and living room requirements.....	34
404.4.1 Room area.....	34
404.4.2 Access from bedrooms.....	34
404.4.3 Water closet accessibility.....	35
404.4.4 Prohibited occupancy.....	35
404.4.5 Other requirements.....	35
404.5 Overcrowding.....	35
TABLE 404.5 MINIMUM AREA REQUIREMENTS.....	35
404.5.1 Sleeping area.....	35
404.5.2 Combined spaces.....	35
404.6 Efficiency unit.....	35
404.7 Food preparation.....	36
CHAPTER 5 PLUMBING FACILITIES AND FIXTURE REQUIREMENTS	37
SECTION 501 GENERAL	37
501.1 Scope.....	37
501.2 Responsibility.....	37
SECTION 502 REQUIRED FACILITIES	37
502.1 Dwelling units.....	37
502.2 Rooming houses.....	37
502.3 Hotels.....	37
502.4 Employees' facilities.....	37
502.4.1 Drinking facilities.....	37
502.5 Public toilet facilities.....	37
SECTION 503 TOILET ROOMS.....	38
503.1 Privacy.....	38
503.2 Location.....	38
503.3 Location of employee toilet facilities.....	38
503.4 Floor surface.....	38

SECTION 504 PLUMBING SYSTEMS AND FIXTURES	38
504.1 General.....	38
504.2 Fixture clearances.	39
504.3 Plumbing system hazards.	39
SECTION 505 WATER SYSTEM.....	39
505.1 General.....	39
505.2 Contamination.	39
505.3 Supply.....	39
505.4 Water heating facilities.....	39
SECTION 506 SANITARY DRAINAGE SYSTEM	39
506.1 General.....	39
506.2 Maintenance.	40
506.3 Grease interceptors.	40
506.4 Sump pump discharge.	40
SECTION 507 STORM DRAINAGE	40
507.1 Roof drainage.....	40
507.2 Sump pump discharge.	40
CHAPTER 6 MECHANICAL AND ELECTRICAL REQUIREMENTS.....	41
SECTION 601 GENERAL	41
601.1 Scope.....	41
601.2 Responsibility.....	41
SECTION 602 HEATING FACILITIES	41
602.1 Facilities required.....	41
602.2 Residential occupancies.	41
602.3 Heat supply.	41
602.4 Occupiable work spaces.....	42
602.5 Room temperature measurement.....	42
602.6 Prohibited method of heating.	42
SECTION 603 MECHANICAL EQUIPMENT.....	42
603.1 Mechanical appliances.....	42
603.2 Removal of combustion products.....	42
603.3 Clearances.....	42

603.4 Safety controls.....	42
603.5 Combustion air.....	42
603.6 Energy conservation devices.....	42
SECTION 604 ELECTRICAL FACILITIES.....	43
604.1 Facilities required.....	43
604.2 Service.....	43
604.3 Electrical system hazards.....	43
604.3.1 Abatement of electrical hazards associated with water exposure.....	43
604.3.1.1 Electrical equipment.....	43
604.3.2 Abatement of electrical hazards associated with fire exposure.....	44
604.3.2.1 Electrical equipment.....	44
SECTION 605 ELECTRICAL EQUIPMENT.....	44
605.1 Installation.....	44
605.2 Receptacles.....	44
605.3 Luminaires.....	45
605.4 Wiring.....	45
SECTION 606 ELEVATORS, ESCALATORS AND DUMBWAITERS.....	45
606.1 General.....	45
606.2 Elevators.....	45
SECTION 607 DUCT SYSTEMS.....	45
607.1 General.....	45
CHAPTER 7 FIRE SAFETY REQUIREMENTS.....	46
SECTION 701 GENERAL.....	46
701.1 Scope.....	46
701.2 Responsibility.....	46
701.3 Applicability of International Fire Code.....	46
SECTION 702 MEANS OF EGRESS.....	46
702.1 General.....	46
702.2 Aisles.....	46
702.3 Locked doors.....	46
702.4 Emergency escape openings.....	46
SECTION 703 FIRE-RESISTANCE RATINGS.....	47

703.1 Fire-resistance-rated assemblies.....	47
703.2 Opening protectives.....	47
703.3 Fire Sprinkler Area.....	46
SECTION 704 FIRE PROTECTION SYSTEMS.....	47
704.1 General.....	47
704.1.1 Automatic sprinkler systems.....	47
704.1.2 Fire department connection.....	47
704.2 Single- and multiple-station smoke alarms.....	47
704.2.1 Where required.....	47
704.2.1.1 Group R-1.....	48
704.2.1.2 Groups R-2, R-3, R-4 and I-1.....	48
704.2.1.3 Installation near cooking appliances.....	48
704.2.1.4 Installation near bathrooms.....	49
704.2.2 Interconnection.....	49
704.2.3 Power source.....	49
704.2.4 Smoke detection system.....	50
704.2.5 Tampering.....	50
704.2.6 Maintenance.....	50
CHAPTER 8 REFERENCED STANDARDS.....	51

CHAPTER 1

SCOPE AND ADMINISTRATION

PART 1 — SCOPE AND APPLICATION

SECTION 101 GENERAL

101.1 Title.

These regulations shall be known as the *International Property Maintenance Code of Manheim Township*, hereinafter referred to as “this code.”

101.2 Scope.

The provisions of this code shall apply to all existing residential and nonresidential structures and all existing *premises* and constitute minimum requirements and standards for *premises*, structures, equipment and facilities for light, *ventilation*, space, heating, sanitation, protection from the elements, a reasonable level of safety from fire and other hazards, and for a reasonable level of sanitary maintenance; the responsibility of *owners*, an owner’s authorized agent, *operators* and *occupants*; the *occupancy* of existing structures and *premises*, and for administration, enforcement and penalties.

101.3 Intent.

This code shall be construed to secure its expressed intent, which is to ensure public health, safety and welfare insofar as they are affected by the continued *occupancy* and maintenance of structures and *premises*. Existing structures and *premises* that do not comply with these provisions shall be altered or repaired to provide a minimum level of health and safety as required herein.

101.4 Severability.

If a section, subsection, sentence, clause or phrase of this code is, for any reason, held to be unconstitutional, such decision shall not affect the validity of the remaining portions of this code.

SECTION 102 APPLICABILITY

102.1 General.

Where there is a conflict between a general requirement and a specific requirement, the specific requirement shall govern. Where differences occur between provisions of this code and the referenced standards, the provisions of this code shall apply. Where, in a specific case, different sections of this code specify different requirements, the most restrictive shall govern.

102.2 Maintenance.

Equipment, systems, devices and safeguards required by this code or a previous regulation or code under which the structure or *premises* was constructed, altered or repaired shall be maintained in good working order. No *owner*, owner’s authorized agent, *operator* or *occupant* shall cause any service, facility, equipment or utility that is required under this section to be removed from, shut off from or discontinued for any occupied dwelling, except for such temporary interruption as necessary while repairs or alterations are in progress. The

requirements of this code are not intended to provide the basis for removal or abrogation of fire protection and safety systems and devices in existing structures. Except as otherwise specified herein, the *owner* or the *owner's* authorized agent shall be responsible for the maintenance of buildings, structures and *premises*.

102.3 Application of other codes.

Repairs, additions or alterations to a structure, or changes of *occupancy*, shall be done in accordance with the procedures and provisions of the *International Building Code, International Existing Building Code, International Energy Conservation Code, International Fire Code, International Fuel Gas Code, International Mechanical Code, International Residential Code, International Plumbing Code* and NFPA 70. Nothing in this code shall be construed to cancel, modify or set aside any provision of the *Zoning Ordinance of Manheim Township 2014, as amended*.

102.4 Existing remedies.

The provisions in this code shall not be construed to abolish or impair existing remedies of the jurisdiction or its officers or agencies relating to the removal or demolition of any structure that is dangerous, unsafe and insanitary.

102.5 Workmanship.

Repairs, maintenance work, alterations or installations that are caused directly or indirectly by the enforcement of this code shall be executed and installed in a *workmanlike* manner and installed in accordance with the manufacturer's instructions.

102.6 Historic buildings.

The provisions of this code shall not be mandatory for existing buildings or structures designated as historic buildings where such buildings or structures are judged by the *code official* to be safe and in the public interest of health, safety and welfare.

102.7 Referenced codes and standards.

The codes and standards referenced in this code shall be those that are listed in Chapter 8 and considered part of the requirements of this code to the prescribed extent of each such reference and as further regulated in Sections 102.7.1 and 102.7.2.

Exception: Where enforcement of a code provision would violate the conditions of the listing of the equipment or appliance, the conditions of the listing shall apply.

102.7.1 Conflicts.

Where conflicts occur between provisions of this code and the referenced standards, the provisions of this code shall apply.

102.7.2 Provisions in referenced codes and standards.

Where the extent of the reference to a referenced code or standard includes subject matter that is within the scope of this code, the provisions of this code, as applicable, shall take precedence over the provisions in the referenced code or standard.

102.8 Requirements not covered by code.

Requirements necessary for the strength, stability or proper operation of an existing fixture, structure or equipment, or for the public safety, health and general welfare, not specifically covered by this code, shall be determined by the *Director of Code Compliance*.

102.9 Application of references.

References to chapter or section numbers, or to provisions not specifically identified by number, shall be construed to refer to such chapter, section or provision of this code.

102.10 Other laws.

The provisions of this code shall not be deemed to nullify any provisions of local, state or federal law.

PART 2 — ADMINISTRATION AND ENFORCEMENT

**SECTION 103
DEPARTMENT OF PROPERTY
MAINTENANCE INSPECTION**

103.1 General.

The Property Maintenance Code of Manheim Township shall be enforced by the Manheim Township Department of Code Compliance. The Department of Code Compliance consists of the Director of Code Compliance and those persons appointed by the Commissioners of Manheim Township to assist him. Such persons are known as Code Officials. All references to a "code official" in this code shall mean the Director of Code Compliance or the Code Officials, as the case may be.

103.2 Liability.

The *code official*, member of the board of appeals or employee charged with the enforcement of this code, while acting for the jurisdiction, in good faith and without malice in the discharge of the duties required by this code or other pertinent law or ordinance, shall not thereby be rendered civilly or criminally liable personally, and is hereby relieved from all personal liability for any damage accruing to persons or property as a result of an act or by reason of an act or omission in the discharge of official duties.

103.2.1 Legal defense.

Any suit or criminal complaint instituted against any officer or employee because of an act performed by that officer or employee in the lawful discharge of duties and under the provisions of this code shall be defended by the legal representative of the jurisdiction until the final termination of the proceedings. The code official or any subordinate shall not be liable for costs in an action, suit or proceeding that is instituted in pursuance of the provisions of this code.

103.3 Fees.

The fees for activities and services performed by the department in carrying out its responsibilities under this code shall be as indicated in the current Manheim Township Fee Resolution.

**SECTION 104
DUTIES AND POWERS OF THE CODE OFFICIAL**

104.1 General.

The *code official* is hereby authorized and directed to enforce the provisions of this code. The

code official shall have the authority to render interpretations of this code and to adopt policies and procedures in order to clarify the application of its provisions. Such interpretations, policies and procedures shall be in compliance with the intent and purpose of this code. Such policies and procedures shall not have the effect of waiving requirements specifically provided for in this code.

104.2 Inspections.

The *code official* shall make all of the required inspections, or shall accept reports of inspection by *approved* agencies or individuals. Reports of such inspections shall be in writing and be certified by a responsible officer of such *approved* agency or by the responsible individual. The *code official* is authorized to engage such expert opinion as deemed necessary to report upon unusual technical issues that arise, subject to the approval of the appointing authority.

104.3 Right of entry.

Where it is necessary to make an inspection to enforce the provisions of this code, or whenever the *code official* has reasonable cause to believe that there exists in a *structure* or upon a *premises* a condition in violation of this code, the *code official* is authorized to enter the structure or *premises* at reasonable times to inspect or perform the duties imposed by this code, provided that if such *structure* or *premises* is occupied the *code official* shall present credentials to the *occupant* and request entry. If such structure or *premises* is unoccupied, the *code official* shall first make a reasonable effort to locate the *owner*, *owner's* authorized agent or other person having charge or control of the *structure* or *premises* and request entry. If entry is refused, the *code official* shall have recourse to the remedies provided by law to secure entry.

104.3.1 Refusal of entry. If any owner, occupant or other person in charge of a structure subject to the provision of this code refuses, impedes, inhibits, interferes with, restricts or obstructs entry and free access to any part of the structure or premises where inspection authorized by this code is sought, the code official may promptly apply for a search or inspection warrant to a court of competent jurisdiction and shall supply all necessary affidavits and testimony to indicate that there is a reasonable or probable cause to conduct an inspection. For the purposes of this section, a reasonable or probable cause to gain access for an inspection shall include, without being limited to, the following:

1. That the inspection of the area is part of a planned routine inspection being conducted pursuant to a systematic or concentrated code enforcement program in that portion of the Township; or
2. That the Code Compliance Department, after investigation or upon information received, has knowledge, information or a reasonable belief that a violation of this code or other codes and ordinances of the Township exist; or
3. That such entry is for the purpose of inspecting a previous notice of violation;
or
4. That the Code Compliance Department has received a complaint concerning a violation on or within the premises; or

5. That such entry is necessary to determine if the building, structure, premises, dwelling or dwelling units meet the standards of this code and building, fire, and health codes and for the safety and welfare of the public.

104.3.2 Right of entry by owner. Every occupant of a dwelling unit, building, structure or premises shall give the owner thereof, or his agent or employee access to any part of such dwelling, dwelling unit, building, structure or premises, at all reasonable times for the purpose of conducting inspections to determine whether or not a violation of the code may exist, or for the purpose of making such repairs or alterations as are necessary to effect compliance with the provisions of this code or with any lawful rule or regulation adopted or any lawful order issued pursuant to the provisions of this code.

Section 104.3.3 Notification to tenants. Every owner of a dwelling unit, building, structure or premises shall give the tenants thereof notice of an inspection and obtain their authorization to grant a code official entry to their unit. If the tenant(s) object(s) to entry by the code official, the owner shall so notify the code official.

104.4 Identification.

The *code official* shall carry proper identification when inspecting *structures* or *premises* in the performance of duties under this code.

104.5 Notices and orders.

The *code official* shall issue all necessary notices or orders to ensure compliance with this code.

104.6 Department records.

The *code official* shall keep official records of all business and activities of the department specified in the provisions of this code. Such records shall be retained in the official records for the period required for retention of public records.

**SECTION 105
APPROVAL**

105.1 Modifications.

Whenever there are practical difficulties involved in carrying out the provisions of this code, the *code official* shall have the authority to grant modifications for individual cases upon application of the *owner* or *owner's* authorized agent, provided the *code official* shall first find that special individual reason makes the strict letter of this code impractical, the modification is in compliance with the intent and purpose of this code and that such modification does not lessen health, life and fire safety requirements. The details of action granting modifications shall be recorded and entered in the department files.

105.2 Alternative materials, methods and equipment.

The provisions of this code are not intended to prevent the installation of any material or to prohibit any method of construction not specifically prescribed by this code, provided that any such alternative has been *approved*. An alternative material or method of construction shall be *approved* where the *code official* finds that the proposed design is satisfactory and complies with the intent of the provisions of this code, and that the material, method or work offered is, for the purpose intended, at least the equivalent of that prescribed in this code in quality, strength, effectiveness, fire resistance, durability and safety. Where the alternative material, design or

method of construction is not *approved*, the *code official* shall respond in writing, stating the reasons the alternative was not *approved*.

105.3 Required testing.

Whenever there is insufficient evidence of compliance with the provisions of this code or evidence that a material or method does not conform to the requirements of this code, or in order to substantiate claims for alternative materials or methods, the *code official* shall have the authority to require tests to be made as evidence of compliance at no expense to the jurisdiction.

105.3.1 Test methods.

Test methods shall be as specified in this code or by other recognized test standards. In the absence of recognized and accepted test methods, the *code official* shall be permitted to approve appropriate testing procedures performed by an *approved agency*.

105.3.2 Test reports.

Reports of tests shall be retained by the *code official* for the period required for retention of public records.

105.4 Used material and equipment.

The use of used materials that meet the requirements of this code for new materials is permitted. Materials, equipment and devices shall not be reused unless such elements are in good repair or have been reconditioned and tested where necessary, placed in good and proper working condition and *approved* by the *code official*.

105.5 Approved materials and equipment.

Materials, equipment and devices *approved* by the *code official* shall be constructed and installed in accordance with such approval.

105.6 Research reports.

Supporting data, where necessary to assist in the approval of materials or assemblies not specifically provided for in this code, shall consist of valid research reports from *approved* sources.

SECTION 106 VIOLATIONS

106.1 Unlawful acts.

It shall be unlawful for a person, firm or corporation to be in conflict with or in violation of any of the provisions of this code.

106.2 Notice of violation.

The *code official* shall serve a notice of violation or order in accordance with Section 107.

106.3 Prosecution of violation.

Any person failing to comply with a notice of violation or order served in accordance with Section 107 shall be deemed guilty of a summary offense or civil infraction as determined by the local municipality, and the violation shall be deemed a *strict liability offense*. If the notice of violation is not complied with, the *code official* shall institute the appropriate proceeding at law or in equity to restrain, correct or abate such violation, or to require the removal or termination of

the unlawful *occupancy* of the structure in violation of the provisions of this code or of the order or direction made pursuant thereto. Any action taken by the authority having jurisdiction on such *premises* shall be charged against the real estate upon which the structure is located and shall be a lien upon such real estate.

106.4 Violation penalties.

Any person who shall violate a provision of this code, or fail to comply therewith, or with any of the requirements thereof, shall be prosecuted within the limits provided by state or local laws. Any person convicted of violating a provision of this code shall be sentenced to pay a fine of not less than \$75 nor more than \$500 for the first two continual and uncorrected violations of the same subsection on the same property and not less than \$150 nor more than \$1,000 for the third and subsequent continual and uncorrected violation of the same subsection of the code on the same property, plus costs and restitution. Every section of this code that is violated shall constitute a separate offense punishable by a separate fine as set forth herein. Each day that a violation continues after due notice has been served shall be deemed a separate offense punishable by a separate fine as set forth herein.

106.5 Abatement of violation.

The imposition of the penalties herein prescribed shall not preclude the legal officer of the jurisdiction from instituting appropriate action to restrain, correct or abate a violation, or to prevent illegal *occupancy* of a building, structure or *premises*, or to stop an illegal act, conduct, business or utilization of the building, structure or *premises*.

Section 106.6 Extensions. Upon application, an extension of time beyond that given on the correction order to bring the violations set forth on the inspection into compliance with this code may be granted for a reasonable cause. An application for extension shall include:

- (a) Name, address and phone number of applicant;
- (b) Address of property referenced on correction order; and
- (c) Violation(s) referenced on correction order for which an extension is being requested.

SECTION 107 NOTICES AND ORDERS

107.1 Notice to person responsible.

Whenever the *code official* determines that there has been a violation of this code or has grounds to believe that a violation has occurred, notice shall be given in the manner prescribed in Sections 107.2 and 107.3 to the person responsible for the violation as specified in this code. Notices for condemnation procedures shall also comply with Section 108.3. No notice shall be required when a property is open and unsecured and the code official has determined that the property shall be secured. The code official may order the structure secured.

107.2 Form.

Such notice prescribed in Section 107.1 shall be in accordance with all of the following:

1. Be in writing.
2. Include a description of the real estate sufficient for identification.
3. Include a statement of the violation or violations and why the notice is being issued.
4. Include a correction order allowing a reasonable time to make the repairs and improvements required to bring the *dwelling unit* or structure into compliance with the provisions of this code.
5. Inform the property *owner* or owner's authorized agent of the right to appeal.
6. Include a statement of the right to file a lien in accordance with Section 106.3.

107.3 Method of service.

Such notice shall be deemed to be properly served if a copy thereof is:

1. Delivered personally;
2. Sent by certified or first-class mail addressed to the last known address; or
3. If the notice is returned showing that the letter was not delivered, a copy thereof shall be posted in a conspicuous place in or about the structure affected by such notice.

107.4 Unauthorized tampering.

Signs, tags or seals posted or affixed by the *code official* shall not be mutilated, destroyed or tampered with, or removed without authorization from the *code official*.

107.5 Penalties.

Penalties for noncompliance with orders and notices shall be as set forth in Section 106.4.

107.6 Transfer of ownership.

It shall be unlawful for the *owner* of any *dwelling unit* or structure who has received a compliance order or upon whom a notice of violation has been served to sell, transfer, mortgage, lease or otherwise dispose of such *dwelling unit* or structure to another until the provisions of the compliance order or notice of violation have been complied with, or until such *owner* or the owner's authorized agent shall first furnish the grantee, transferee, mortgagee or lessee a true copy of any compliance order or notice of violation issued by the *code official* and shall furnish to the *code official* a signed and notarized statement from the grantee, transferee, mortgagee or lessee, acknowledging the receipt of such compliance order or notice of violation and fully accepting the responsibility without condition for making the corrections or repairs required by such compliance order or notice of violation.

SECTION 108 UNSAFE STRUCTURES, EQUIPMENT AND PREMISES

108.1 General.

When a structure or equipment is found by the *code official* to be unsafe, or when a structure is found unfit for human *occupancy*, or is found unlawful, such structure shall be *condemned* pursuant to the provisions of this code.

108.1.1 Unsafe structures.

An unsafe structure is one that is found to be dangerous to the life, health, property or safety of the public or the *occupants* of the structure by not providing minimum safeguards to protect or warn *occupants* in the event of fire, or because such structure contains unsafe equipment or is so damaged, decayed, dilapidated, structurally unsafe or of such faulty construction or unstable foundation, that partial or complete collapse is possible.

108.1.2 Unsafe equipment.

Unsafe equipment includes any boiler, heating equipment, elevator, moving stairway, electrical wiring or device, flammable liquid containers or other equipment on the *premises* or within the structure which is in such disrepair or condition that such equipment is a hazard to life, health, property or safety of the public or *occupants* of the *premises* or structure.

108.1.3 Structure unfit for human occupancy.

A structure is unfit for human *occupancy* whenever the *code official* finds that such structure is unsafe, unlawful or, because of the degree to which the structure is in disrepair or lacks maintenance, is insanitary, vermin or rat infested, contains filth and contamination, or lacks *ventilation*, illumination, sanitary or heating facilities or other essential equipment required by this code, or because the location of the structure constitutes a hazard to the *occupants* of the structure or to the public.

108.1.4 Unlawful structure.

An unlawful structure is one found in whole or in part to be occupied by more persons than permitted under this code, or was erected, altered or occupied contrary to law.

108.1.5 Dangerous structure or premises.

For the purpose of this code, any structure or *premises* that has any or all of the conditions or defects described below shall be considered dangerous:

1. Any door, aisle, passageway, stairway, exit or other means of egress that does not conform to the *approved* building or fire code of the jurisdiction as related to the requirements for existing buildings.
2. The walking surface of any aisle, passageway, stairway, exit or other means of egress is so warped, worn loose, torn or otherwise unsafe as to not provide safe and adequate means of egress.
3. Any portion of a building, structure or appurtenance that has been damaged by fire, earthquake, wind, flood, *deterioration*, *neglect*, abandonment, vandalism or by any other cause to such an extent that it is likely to partially or completely collapse, or to become *detached* or dislodged.
4. Any portion of a building, or any member, appurtenance or ornamentation on the exterior thereof that is not of sufficient strength or stability, or is not so *anchored*, attached or fastened in place so as to be capable of resisting natural or artificial loads of one and one-half the original designed value.
5. The building or structure, or part of the building or structure, because of dilapidation, *deterioration*, decay, faulty construction, the removal or movement of some portion of the ground necessary for the support, or for any other reason,

is likely to partially or completely collapse, or some portion of the foundation or underpinning of the building or structure is likely to fail or give way.

6. The building or structure, or any portion thereof, is clearly unsafe for its use and *occupancy*.
7. The building or structure is *neglected*, damaged, dilapidated, unsecured or abandoned so as to become an attractive nuisance to children who might play in the building or structure to their danger, becomes a harbor for vagrants, criminals or immoral persons, or enables persons to resort to the building or structure for committing a nuisance or an unlawful act.
8. Any building or structure has been constructed, exists or is maintained in violation of any specific requirement or prohibition applicable to such building or structure provided by the *approved* building or fire code of the jurisdiction, or of any law or ordinance to such an extent as to present either a substantial risk of fire, building collapse or any other threat to life and safety.
9. A building or structure, used or intended to be used for dwelling purposes, because of inadequate maintenance, dilapidation, decay, damage, faulty construction or arrangement, inadequate light, *ventilation*, mechanical or plumbing system, or otherwise, is determined by the *code official* to be unsanitary, unfit for human habitation or in such a condition that is likely to cause sickness or disease.
10. Any building or structure, because of a lack of sufficient or proper fire-resistance-rated construction, fire protection systems, electrical system, fuel connections, mechanical system, plumbing system or other cause, is determined by the *code official* to be a threat to life or health.
11. Any portion of a building remains on a site after the demolition or destruction of the building or structure or whenever any building or structure is abandoned so as to constitute such building or portion thereof as an attractive nuisance or hazard to the public.
12. Any *premises* which because of physical condition, use or occupancy is considered an attractive nuisance to children, including but not limited to abandoned wells, shafts, excavations, and unsafe fences or structures.
13. Any premises which because of neglect or lack of maintenance has become a place for accumulation of trash and debris, or a haven for rodents or other vermin.
14. Any unoccupied property which has been tax delinquent a period of two years prior to the effective date of this act, and those in the future having a two-year tax delinquency.
15. Any property which is vacant, but not tax delinquent, and which identified defects have not been eliminated within one year of the receipt of notice to rehabilitate from the Department of Code Compliance.

16. Any abandoned structure or premises. Abandoned shall be defined as:
- (a) A vacant or unimproved lot or parcel of ground on which a municipal lien for the cost of demolition of any structure located on the property remains unpaid for a period of six months;
 - (b) A vacant property or vacant or unimproved lot or parcel of ground on which the total sum of municipal liens on the property for taxes or any other type of municipal claim exceed 150% of the fair market value of the property as established by anybody with legal authority to determine the taxable value of the property; or
 - (c) A property declared abandoned by the owner, including an estate that is in possession of the property.
 - (d) A property which has defective or unusual conditions of title or no known owners, rendering title unmarketable.
 - (e) A property which has environmentally hazardous conditions, solid waste pollution or contamination in a building or on the land which poses a direct and immediate threat to the health, safety and welfare of the community.

108.2 Closing of vacant structures.

If the structure is vacant and unfit for human habitation and *occupancy*, and is not in danger of structural collapse, the *code official* is authorized to post a placard of condemnation on the *premises* and order the structure closed up so as not to be an attractive nuisance. Upon failure of the *owner* or owner's authorized agent to close up the *premises* within the time specified in the order, the *code official* shall cause the *premises* to be closed and secured through any available public agency or by contract or arrangement by private persons and the cost thereof shall be charged against the real estate upon which the structure is located and shall be a lien upon such real estate and shall be collected by any other legal resource.

108.2.1 Authority to disconnect service utilities.

The *code official* shall have the authority to authorize disconnection of utility service to the building, structure or system regulated by this code and the referenced codes and standards set forth in Section 102.7 in case of emergency where necessary to eliminate an immediate hazard to life or property or where such utility connection has been made without approval. The *code official* shall notify the serving utility and, whenever possible, the *owner* or owner's authorized agent and *occupant* of the building, structure or service system of the decision to disconnect prior to taking such action. If not notified prior to disconnection the *owner*, owner's authorized agent or *occupant* of the building structure or service system shall be notified in writing as soon as practical thereafter.

108.3 Notice.

Whenever the *code official* has condemned a structure or equipment under the provisions of this section, notice shall be posted in a conspicuous place in or about the structure affected by such notice and served on the *owner*, owner's authorized agent or the person or persons responsible for the structure or equipment in accordance with Section 107.3. If the notice pertains to equipment, it shall be placed on the condemned equipment. The notice shall be in the form prescribed in Section 107.2.

108.4 Placarding.

Upon failure of the *owner*, owner's authorized agent or person responsible to comply with the notice provisions within the time given, the *code official* shall post on the *premises* or on defective equipment a placard bearing the word "Condemned" and a statement of the penalties provided for occupying the *premises*, operating the equipment or removing the placard.

108.4.1 Placard removal.

The *code official* shall remove the condemnation placard whenever the defect or defects upon which the condemnation and placarding action were based have been eliminated. Any person who defaces or removes a condemnation placard without the approval of the *code official* shall be subject to the penalties provided by this code.

108.5 Prohibited occupancy.

Any occupied structure condemned and placarded by the *code official* shall be vacated as ordered by the *code official*. Any person who shall occupy a placarded *premises* or shall operate placarded equipment, and any *owner*, owner's authorized agent or person responsible for the *premises* who shall let anyone occupy a placarded *premises* or operate placarded equipment shall be liable for the penalties provided by this code.

108.6 Abatement methods.

The *owner*, owner's authorized agent, *operator* or *occupant* of a building, *premises* or equipment deemed unsafe by the *code official* shall abate or cause to be abated or corrected such unsafe conditions either by repair, rehabilitation, demolition or other *approved* corrective action. The *owner*, *operator* or *occupant* of a *building*, *premises* or *equipment* shall notify the code official when the corrective action has been completed. The code official shall then inspect the *building*, *premises*, or *equipment* and shall notify the owner, operator or occupant that the corrective action either does or does not comply with this code. If not, the code official may take such other action as is provided by this code.

108.7 Record.

The *code official* shall cause a report to be filed on an unsafe condition. The report shall state the *occupancy* of the structure and the nature of the unsafe condition.

SECTION 109 EMERGENCY MEASURES

109.1 Imminent danger.

When, in the opinion of the *code official*, there is *imminent danger* of failure or collapse of a building or structure that endangers life, or when any structure or part of a structure has fallen and life is endangered by the occupation of the structure, or when there is actual or potential danger to the building *occupants* or those in the proximity of any structure because of explosives, explosive fumes or vapors or the presence of toxic fumes, gases or materials, or operation of defective or dangerous equipment, the *code official* is hereby authorized and empowered to order and require the *occupants* to vacate the *premises* forthwith. The *code*

official shall cause to be posted at each entrance to such structure a notice reading as follows: "This *Structure* Is Unsafe and Its *Occupancy* Has Been Prohibited by the *Code Official*." It shall be unlawful for any person to enter such structure except for the purpose of securing the structure, making the required repairs, removing the hazardous condition or of demolishing the same.

109.2 Temporary safeguards.

Notwithstanding other provisions of this code, whenever, in the opinion of the *code official*, there is *imminent danger* due to an unsafe condition, the *code official* shall order the necessary work to be done, including the boarding up of openings, to render such structure temporarily safe whether or not the legal procedure herein described has been instituted; and shall cause such other action to be taken as the *code official* deems necessary to meet such emergency.

109.3 Closing streets.

When necessary for public safety, the *code official* shall temporarily close structures and close, or order the authority having jurisdiction to close, sidewalks, streets, *public ways* and places adjacent to unsafe structures, and prohibit the same from being utilized.

109.4 Emergency repairs.

For the purposes of this section, the *code official* shall employ the necessary labor and materials to perform the required work as expeditiously as possible.

109.5 Costs of emergency repairs.

Costs incurred in the performance of emergency work shall be paid by the jurisdiction. The legal counsel of the jurisdiction shall institute appropriate action against the *owner* of the *premises* or owner's authorized agent where the unsafe structure is or was located for the recovery of such costs.

109.6 Hearing.

Any person ordered to take emergency measures shall comply with such order forthwith. Any affected person shall thereafter, upon petition directed to the appeals board, be afforded a hearing as described in this code.

SECTION 110 DEMOLITION

110.1 General.

The *code official* shall order the *owner* or owner's authorized agent of any *premises* upon which is located any structure, which in the *code official's* or owner's authorized agent judgment after review is so deteriorated or dilapidated or has become so out of repair as to be dangerous, unsafe, insanitary or otherwise unfit for human habitation or occupancy, and such that it is unreasonable to repair the structure, to demolish and remove such structure; or if such structure is capable of being made safe by repairs, to repair and make safe and sanitary, or to board up and hold for future repair or to demolish and remove at the *owner's* option; or where there has been a cessation of normal construction of any structure for a period of more than two years, the *code official* shall order the *owner* or owner's authorized agent to demolish and remove such structure, or board up until future repair. Boarding the building up for future repair shall not extend beyond one year, unless *approved* by the building official.

110.2 Notices and orders.

Notices and orders shall comply with Section 107.

110.3 Failure to comply.

If the *owner* of a *premises* or owner's authorized agent fails to comply with a demolition order within the time prescribed, the *code official* shall cause the structure to be demolished and removed, either through an available public agency or by contract or arrangement with private persons, and the cost of such demolition and removal shall be charged against the real estate upon which the structure is located and shall be a lien upon such real estate.

110.4 Salvage materials.

When any structure has been ordered demolished and removed, the governing body or other designated officer under said contract or arrangement aforesaid shall have the right to sell the salvage and valuable materials. The net proceeds of such sale, after deducting the expenses of such demolition and removal, shall be promptly remitted with a report of such sale or transaction, including the items of expense and the amounts deducted, for the person who is entitled thereto, subject to any order of a court. If such a surplus does not remain to be turned over, the report shall so state.

SECTION 111 MEANS OF APPEAL

111.1 Application for appeal.

Any person directly affected by a decision of the *code official* or a notice or order issued under this code shall have the right to appeal to the Manheim Township Uniform Construction Code (UCC) Board of Appeals, provided that a written application for appeal is filed within 20 days after the day the decision, notice or order was served. An application for appeal shall be based on a claim that the true intent of this code or the rules legally adopted thereunder have been incorrectly interpreted, the provisions of this code do not fully apply, or the requirements of this code are adequately satisfied by other means.

111.2 Notice of meeting.

The board shall meet upon notice from the chairman, within 20 days of the filing of an appeal, or at stated periodic meetings.

111.3 Open hearing.

Hearings before the board shall be open to the public. The appellant, the appellant's representative, the *code official* and any person whose interests are affected shall be given an opportunity to be heard. A quorum shall consist of a minimum of two-thirds of the board membership.

111.3.1 Procedure.

The board shall adopt and make available to the public through the secretary procedures under which a hearing will be conducted. The procedures shall not require compliance with strict rules of evidence, but shall mandate that only relevant information be received.

111.4 Postponed hearing.

When the full board is not present to hear an appeal, either the appellant or the appellant's representative shall have the right to request a postponement of the hearing.

111.5 Board decision.

The board shall modify or reverse the decision of the *code official* only by a concurring vote of a majority of the total number of appointed board members.

111.5.1 Records and copies.

The decision of the board shall be recorded. Copies shall be furnished to the appellant and to the *code official*.

111.5.2 Administration.

The *code official* shall take immediate action in accordance with the decision of the board.

111.6 Court review.

Any person aggrieved by any decision of the Manheim Township UCC Board of Appeals or any officer or department of the Township, may appeal the decision to the Court of Common Pleas of Lancaster County, Pennsylvania pursuant to the Local Rules of Court governing Local Agency and Administrative Agency Appeals Other than Land Use Appeals; which appeal must be filed with the Court within 30 days after service of the decision filed by the board.

111.7 Stays of enforcement.

Appeals of notice and orders (other than *Imminent Danger* notices) shall stay the enforcement of the notice and order until the appeal is heard by the appeals board.

**SECTION 112
STOP WORK ORDER**

112.1 Authority.

Whenever the *code official* finds any work regulated by this code being performed in a manner contrary to the provisions of this code or in a dangerous or unsafe manner, the *code official* is authorized to issue a stop work order.

112.2 Issuance.

A stop work order shall be in writing and shall be given to the *owner* of the property, to the *owner's* authorized agent, or to the person doing the work. Upon issuance of a stop work order, the cited work shall immediately cease. The stop work order shall state the reason for the order and the conditions under which the cited work is authorized to resume.

112.3 Emergencies.

Where an emergency exists, the *code official* shall not be required to give a written notice prior to stopping the work.

112.4 Failure to comply.

Any person who shall continue any work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be liable to a fine of not less than \$100.00 dollars or more than \$1,000.00 dollars.

CHAPTER 2 DEFINITIONS

SECTION 201 GENERAL

201.1 Scope.

Unless otherwise expressly stated, the following terms shall, for the purposes of this code, have the meanings shown in this chapter.

201.2 Interchangeability.

Words stated in the present tense include the future; words stated in the masculine gender include the feminine and neuter; the singular number includes the plural and the plural, the singular.

201.3 Terms defined in other codes.

Where terms are not defined in this code and are defined in the *International Building Code*, *International Existing Building Code*, *International Fire Code*, *International Fuel Gas Code*, *International Mechanical Code*, *International Plumbing Code*, *International Residential Code*, *International Zoning Code* or NFPA 70, such terms shall have the meanings ascribed to them as stated in those codes.

201.4 Terms not defined.

Where terms are not defined through the methods authorized by this section, such terms shall have ordinarily accepted meanings such as the context implies.

201.5 Parts.

Whenever the words “*dwelling unit*,” “*dwelling*,” “*premises*,” “*building*,” “*rooming house*,” “*rooming unit*,” “*housekeeping unit*” or “*story*” are stated in this code, they shall be construed as though they were followed by the words “or any part thereof.”

SECTION 202 GENERAL DEFINITIONS

ANCHORED. Secured in a manner that provides positive connection.

APPROVED. Acceptable to the *code official*.

BASEMENT. That portion of a building which is partly or completely below grade.

BATHROOM. A room containing plumbing fixtures including a bathtub or shower.

BEDROOM. Any room or space used or intended to be used for sleeping purposes in either a dwelling or *sleeping unit*.

CODE OFFICIAL. The official who is charged with the administration and enforcement of this code, or any duly authorized representative.

CONDEMN. To adjudge unfit for *occupancy*.

COST OF SUCH DEMOLITION OR EMERGENCY REPAIRS. The costs shall include the actual costs of the demolition or repair of the structure less revenues obtained if salvage was conducted prior to demolition or repair. Costs shall include, but not be limited to, expenses incurred or necessitated related to demolition or emergency repairs, such as asbestos survey and abatement if necessary; costs of inspectors, testing agencies or experts retained relative to the demolition or emergency repairs; costs of testing; surveys for other materials that are controlled or regulated from being dumped in a landfill; title searches; mailing(s); postings; recording; and attorney fees expended for recovering of the cost of emergency repairs or to obtain or enforce an order of demolition made by a *code official*, the governing body or board of appeals.

DETACHED. When a structural element is physically disconnected from another and that connection is necessary to provide a positive connection.

DETERIORATION. To weaken, disintegrate, corrode, rust or decay and lose effectiveness.

DWELLING UNIT. A single unit providing complete, independent living facilities for one or more persons, including permanent provisions for living, sleeping, eating, cooking and sanitation.

EASEMENT. That portion of land or property reserved for present or future use by a person or agency other than the legal fee *owner(s)* of the property. The *easement* shall be permitted to be for use under, on or above a said lot or lots.

EQUIPMENT SUPPORT. Those structural members or assemblies of members or manufactured elements, including braces, frames, lugs, snuggers, hangers or saddles, that transmit gravity load, lateral load and operating load between the equipment and the structure.

EXTERIOR PROPERTY. The open space on the *premises* and on adjoining property under the control of *owners* or *operators* of such *premises*.

GARBAGE. The animal or vegetable waste resulting from the handling, preparation, cooking and consumption of food.

GUARD. A building component or a system of building components located at or near the open sides of elevated walking surfaces that minimizes the possibility of a fall from the walking surface to a lower level.

HABITABLE SPACE. Space in a structure for living, sleeping, eating or cooking. *Bathrooms, toilet rooms, closets, halls, storage or utility spaces, and similar areas are not considered habitable spaces.*

HEATING FACILITY. A fixed, non-portable heating equipment or unit.

HISTORIC BUILDING. Any building or structure that is one or more of the following:

1. Listed or certified as eligible for listing, by the State Historic Preservation Officer or the Keeper of the National Register of Historic Places, in the National Register of Historic Places.

2. Designated as historic under an applicable state or local law.
3. Certified as a contributing resource within a National Register or state or locally designated historic district.

HOUSEKEEPING UNIT. A room or group of rooms forming a single *habitable space* equipped and intended to be used for living, sleeping, cooking and eating which does not contain, within such a unit, a toilet, lavatory and bathtub or shower.

IMMINENT DANGER. A condition which could cause serious or life-threatening injury or death at any time.

INFESTATION. The presence, within or contiguous to, a structure or *premises* of insects, rodents, vermin or other pests.

INOPERABLE MOTOR VEHICLE. A vehicle which cannot be driven upon the public streets for reason including but not limited to being unlicensed, wrecked, abandoned, in a state of disrepair, or incapable of being moved under its own power.

LABELED. Equipment, materials or products to which have been affixed a label, seal, symbol or other identifying mark of a nationally recognized testing laboratory, inspection agency or other organization concerned with product evaluation that maintains periodic inspection of the production of the above-*labeled* items and whose labeling indicates either that the equipment, material or product meets identified standards or has been tested and found suitable for a specified purpose.

LAVATORY. A fixed washbowl with running water and drainpipe (sink).

LET FOR OCCUPANCY or LET. To permit, provide or offer possession or *occupancy* of a dwelling, *dwelling unit*, *rooming unit*, building, premise or structure by a person who is or is not the legal *owner* of record thereof, pursuant to a written or unwritten lease, agreement or license, or pursuant to a recorded or unrecorded agreement of contract for the sale of land.

NEGLECT. The lack of proper maintenance for a building or *structure*.

OCCUPANCY. The purpose for which a building or portion thereof is utilized or occupied.

OCCUPANT. Any individual living or sleeping in a building, or having possession of a space within a building.

OPENABLE AREA. That part of a window, skylight or door which is available for unobstructed *ventilation* and which opens directly to the outdoors.

OPERATOR. Any person who has charge, care or control of a structure or *premises* which is let or offered for *occupancy*.

OWNER. Any person, agent, *operator*, firm or corporation having legal or equitable interest in the property; or recorded in the official records of the state, county or municipality as holding title to the property; or otherwise having control of the property, including the guardian of the estate

of any such person, and the executor or administrator of the estate of such person if ordered to take possession of real property by a court.

PERSON. An individual, corporation, partnership or any other group acting as a unit.

PEST ELIMINATION. The control and elimination of insects, rodents or other pests by eliminating their harborage places; by removing or making inaccessible materials that serve as their food or water; by other *approved pest elimination* methods.

PLUMBING. Refers to water pipes, waste pipes, water closets, sinks, installed dishwashers, lavatories, bath tubs, shower baths, installed clothes-washing machines, catch basins, drains, garbage disposal units, as well as gas pipes, and gas-burning equipment, water heating facilities and vents and other similar supply fixtures, together with all connections to water, sewer and gas lines.

PREMISES. A lot, plot or parcel of land, *easement* or *public way*, including any structures thereon.

PUBLIC WAY. Any street, alley or similar parcel of land essentially unobstructed from the ground to the sky, which is deeded, dedicated or otherwise permanently appropriated to the public for public use.

ROOMING HOUSE. A building arranged or occupied for lodging, with or without meals, for compensation and not occupied as a one- or two-family dwelling.

ROOMING UNIT. Any room or group of rooms forming a single habitable unit occupied or intended to be occupied for sleeping or living, but not for cooking purposes.

RUBBISH. Combustible and noncombustible waste materials, except garbage; the term shall include the residue from the burning of wood, coal, coke and other combustible materials, paper, rags, cartons, boxes, wood, excelsior, rubber, leather, tree branches, *yard* trimmings, tin cans, metals, mineral matter, glass, crockery and dust and other similar materials.

SLEEPING UNIT. A room or space in which people sleep, which can also include permanent provisions for living, eating and either sanitation or kitchen facilities, but not both. Such rooms and spaces that are also part of a *dwelling unit* are not *sleeping units*.

STRICT LIABILITY OFFENSE. An offense in which the prosecution in a legal proceeding is not required to prove criminal intent as a part of its case. It is enough to prove that the defendant either did an act which was prohibited, or failed to do an act which the defendant was legally required to do.

STRUCTURE. That which is built or constructed or a portion thereof.

TENANT. A person, corporation, partnership or group, whether or not the legal *owner* of record, occupying a building or portion thereof as a unit.

TOILET ROOM. A room containing a water closet or urinal but not a bathtub or shower.

ULTIMATE DEFORMATION. The deformation at which failure occurs and which shall be deemed to occur if the sustainable load reduces to 80 percent or less of the maximum strength.

VENTILATION. The natural or mechanical process of supplying conditioned or unconditioned air to, or removing such air from, any space.

WATER CLOSET. A compartment or room with plumbing fixtures used for the elimination of bodily wastes (toilet bowls and urinals).

WORKMANLIKE. Executed in a skilled manner; e.g., generally plumb, level, square, in line, undamaged and without marring adjacent work.

YARD. An open space on the same lot with a structure.

CHAPTER 3 GENERAL REQUIREMENTS

SECTION 301 GENERAL

301.1 Scope.

The provisions of this chapter shall govern the minimum conditions and the responsibilities of persons for maintenance of structures, equipment and *exterior property*.

301.2 Responsibility.

The *owner* of the *premises* shall maintain the structures and *exterior property* in compliance with these requirements, except as otherwise provided for in this code. A person shall not occupy as owner-occupant or permit another person to occupy *premises* that are not in a sanitary and safe condition and that do not comply with the requirements of this chapter. *Occupants* of a *dwelling unit*, *rooming unit* or *housekeeping unit* are responsible for keeping in a clean, sanitary and safe condition that part of the *dwelling unit*, *rooming unit*, *housekeeping unit* or *premises* which they occupy and control.

301.3 Vacant structures and land.

Vacant structures and *premises* thereof or vacant land shall be maintained in a clean, safe, secure and sanitary condition as provided herein so as not to cause a blighting problem or adversely affect the public health or safety.

301.3.1 Exterior conditions.

The exterior of every vacant structure, accessory structure or *premises* shall be maintained free of broken windows, loose or deteriorating shingles, siding or decorative features or building materials, crumbling stone or brick, or excessive peeling paint.

SECTION 302 EXTERIOR PROPERTY AREAS

302.1 Sanitation.

Exterior property and *premises* shall be maintained in a clean, safe and sanitary condition. The *occupant* shall keep that part of the *exterior property* that such *occupant* occupies or controls in a clean and sanitary condition free of any offensive odor(s).

302.2 Grading and drainage.

Premises shall be graded and maintained to prevent the erosion of soil and to prevent the accumulation of stagnant water thereon, or within any structure located thereon.

Exception: *Approved* retention areas and reservoirs.

302.3 Sidewalks and driveways.

Sidewalks, walkways, stairs, driveways, parking spaces and similar areas shall be kept in a proper state of repair, and maintained free from hazardous conditions. The exit discharge(s) as defined in the International Building Code shall be kept in a proper state of repair, and

maintained free from hazardous conditions.

302.4 Weeds.

Premises and *exterior property* shall be maintained free from weeds or plant growth in excess of 6 inches in height. Noxious weeds shall be prohibited. Weeds shall be defined as all grasses, annual plants and vegetation, other than trees or shrubs provided; however, this term shall not include cultivated flowers and gardens.

Upon failure of the *owner* or agent having charge of a property to cut and destroy weeds after service of a notice of violation, they shall be subject to prosecution in accordance with Section 106.3 and as prescribed by the authority having jurisdiction. Upon failure to comply with the notice of violation, any duly authorized employee of the jurisdiction or contractor hired by the jurisdiction shall be authorized to enter upon the property in violation and cut and destroy the weeds growing thereon, and the costs of such removal shall be paid by the *owner* or agent responsible for the property.

302.5 Rodent harborage.

Structures and *exterior property* shall be kept free from rodent harborage and *infestation*. Where rodents are found, they shall be promptly exterminated by *approved* processes that will not be injurious to human health. After pest elimination, proper precautions shall be taken to eliminate rodent harborage and prevent reinfestation.

302.6 Exhaust vents.

Pipes, ducts, conductors, fans or blowers shall not discharge gases, steam, vapor, hot air, grease, smoke, odors or other gaseous or particulate wastes directly upon abutting or adjacent public or private property or that of another *tenant*.

302.7 Accessory structures.

Accessory structures, including *detached* garages, fences and walls, shall be maintained structurally sound and in good repair.

302.8 Motor vehicles.

Except as provided for in other regulations, no inoperative or unlicensed motor vehicle shall be parked, kept or stored on any *premises*, and no vehicle shall at any time be in a state of major disassembly, disrepair, or in the process of being stripped or dismantled. Painting of vehicles is prohibited unless conducted inside an *approved* spray booth.

Exception: A vehicle of any type is permitted to undergo major overhaul, including body work, provided that such work is performed inside a structure or similarly enclosed area designed and *approved* for such purposes.

302.9 Defacement of property.

No person shall willfully or wantonly damage, mutilate or deface any exterior surface of any structure or building on any private or public property by placing thereon any marking, carving or graffiti.

It shall be the responsibility of the *owner* to restore said surface to an *approved* state of maintenance and repair.

302.10 Trees, bushes and shrubs.

All trees, bushes and shrubs shall be maintained to prevent the creation of a dangerous condition as determined by the code official.

SECTION 303 SWIMMING POOLS, SPAS AND HOT TUBS

303.1 Swimming pools.

Swimming pools shall be maintained in a clean and sanitary condition, and in good repair.

303.2 Enclosures.

Private swimming pools, hot tubs and spas, containing water more than 24 inches (610 mm) in depth shall be completely surrounded by a fence or barrier not less than 48 inches (1219 mm) in height above the finished ground level measured on the side of the barrier away from the pool. Gates and doors in such barriers shall be self-closing and self-latching. Where the self-latching device is less than 54 inches (1372 mm) above the bottom of the gate, the release mechanism shall be located on the pool side of the gate. Self-closing and self-latching gates shall be maintained such that the gate will positively close and latch when released from an open position of 6 inches (152 mm) from the gatepost. No existing pool enclosure shall be removed, replaced or changed in a manner that reduces its effectiveness as a safety barrier.

Exception: Spas or hot tubs with a safety cover that complies with ASTM F 1346 shall be exempt from the provisions of this section.

SECTION 304 EXTERIOR STRUCTURE

304.1 General.

The exterior of a structure shall be maintained in good repair, structurally sound and sanitary so as not to pose a threat to the public health, safety or welfare.

304.1.1 Unsafe conditions.

The following conditions shall be determined as unsafe and shall be repaired or replaced to comply with the *International Building Code* or the *International Existing Building Code* as required for existing buildings:

1. The nominal strength of any structural member is exceeded by nominal loads, the load effects or the required strength;
2. The *anchorage* of the floor or roof to walls or columns, and of walls and columns to foundations is not capable of resisting all nominal loads or load effects;
3. Structures or components thereof that have reached their limit state;
4. Siding and masonry joints including joints between the building envelope and the perimeter of windows, doors and skylights are not maintained, weather resistant or water tight;
5. Structural members that have evidence of *deterioration* or that are not capable of safely supporting all nominal loads and load effects;

6. Foundation systems that are not firmly supported by footings, are not plumb and free from open cracks and breaks, are not properly *anchored* or are not capable of supporting all nominal loads and resisting all load effects;
7. Exterior walls that are not *anchored* to supporting and supported elements or are not plumb and free of holes, cracks or breaks and loose or rotting materials, are not properly *anchored* or are not capable of supporting all nominal loads and resisting all load effects;
8. Roofing or roofing components that have defects that admit rain, roof surfaces with inadequate drainage, or any portion of the roof framing that is not in good repair with signs of *deterioration*, fatigue or without proper anchorage and incapable of supporting all nominal loads and resisting all load effects;
9. Flooring and flooring components with defects that affect serviceability or flooring components that show signs of *deterioration* or fatigue, are not properly *anchored* or are incapable of supporting all nominal loads and resisting all load effects;
10. Veneer, cornices, belt courses, corbels, trim, wall facings and similar decorative features not properly anchored or that are anchored with connections not capable of supporting all nominal loads and resisting all load effects;
11. Overhang extensions or projections including, but not limited to, trash chutes, canopies, marquees, signs, awnings, fire escapes, standpipes and exhaust ducts not properly *anchored* or that are *anchored* with connections not capable of supporting all nominal loads and resisting all load effects;
12. Exterior stairs, decks, porches, balconies and all similar appurtenances attached thereto, including *guards* and handrails, are not structurally sound, not properly *anchored* or that are *anchored* with connections not capable of supporting all nominal loads and resisting all load effects; or
13. Chimneys, cooling towers, smokestacks and similar appurtenances not structurally sound or not properly *anchored*, or that are anchored with connections not capable of supporting all nominal loads and resisting all load effects.

Exceptions:

1. Where substantiated otherwise by an *approved* method.
2. Demolition of unsafe conditions shall be permitted where *approved* by the *code official*.

304.2 Protective treatment.

Exterior surfaces, including but not limited to, doors, door and window frames, cornices, porches, trim, balconies, decks and fences, shall be maintained in good condition. Exterior wood surfaces, other than decay-resistant woods, shall be protected from the elements and decay by painting or other protective covering or treatment. Peeling, flaking and chipped paint shall be eliminated and surfaces repainted. Siding and masonry joints, as well as those between the building envelope and the perimeter of windows, doors and skylights, shall be maintained

weather resistant and water tight. Metal surfaces subject to rust or corrosion shall be coated to inhibit such rust and corrosion, and surfaces with rust or corrosion shall be stabilized and coated to inhibit future rust and corrosion. Oxidation stains shall be removed from exterior surfaces. Surfaces designed for stabilization by oxidation are exempt from this requirement.

304.3 Premises identification.

Buildings shall have *approved* address numbers placed in a position to be plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background.

Residential Structures - The number(s) shall be at least 2-3/4 inches in height and shall be placed at least 18 inches above finished grade. Numbers displayed on the main front door or overhead doors are not permanent in nature and do not count towards the required premise identification.

Nonresidential Structures - The numbers(s) shall be at least 6 inches in height with a minimum stroke of at least 1/2 inch and shall be placed as directed by the Director of Code Compliance. Numbers installed on glass are to be white in color.

Each tenant in a multi-tenant commercial structure shall display numbers at both the front and all rear entrances to the unit.

304.4 Structural members.

Structural members shall be maintained free from *deterioration*, and shall be capable of safely supporting the imposed dead and live loads.

304.5 Foundation walls.

Foundation walls shall be maintained plumb and free from open cracks and breaks and shall be kept in such condition so as to prevent the entry of rodents and other pests.

304.6 Exterior walls.

Exterior walls shall be free from holes, breaks, and loose or rotting materials; and maintained weatherproof and properly surface coated where required to prevent *deterioration*.

304.7 Roofs and drainage.

The roof and flashing shall be sound, tight and not have defects that admit rain. Roof drainage shall be adequate to prevent dampness or *deterioration* in the walls or interior portion of the structure. Roof drains, gutters and downspouts shall be maintained in good repair and free from obstructions. The controlled method of water disposal from roofs shall terminate at least 5 feet from the exterior foundation wall and discharge in a manner that does not create a nuisance on the adjacent property(s), and shall terminate no closer than 10 feet from the street right-of-way.

304.8 Decorative features.

Cornices, belt courses, corbels, terra cotta trim, wall facings and similar decorative features shall be maintained in good repair with proper anchorage and in a safe condition.

304.9 Overhang extensions.

Overhang extensions including, but not limited to, canopies, marquees, signs, metal awnings, fire escapes, standpipes and exhaust ducts shall be maintained in good repair and be properly *anchored* so as to be kept in a sound condition. Where required, all exposed surfaces of metal

or wood shall be protected from the elements and against decay or rust by periodic application of weather-coating materials, such as paint or similar surface treatment.

304.10 Stairways, decks, porches and balconies.

Every exterior stairway, deck, porch and balcony, and all appurtenances attached thereto, shall be maintained structurally sound, in good repair, with proper anchorage and capable of supporting the imposed loads.

304.11 Chimneys and towers.

Chimneys, cooling towers, smoke stacks, and similar appurtenances shall be maintained structurally safe and sound, and in good repair. Exposed surfaces of metal or wood shall be protected from the elements and against decay or rust by periodic application of weather-coating materials, such as paint or similar surface treatment.

304.12 Handrails and guards.

Every handrail and *guard* shall be firmly fastened and capable of supporting normally imposed loads and shall be maintained in good condition. Guards which are deteriorated and deemed unsafe by the Director of Code Compliance shall be repaired and shall comply with the currently adopted guardrail provisions found in the International Residential Code or International Building Code.

304.13 Window, skylight and door frames.

Every window, skylight, door and frame shall be kept in sound condition, good repair and weather tight.

304.13.1 Glazing.

Glazing materials shall be maintained free from cracks and holes.

304.13.2 Openable windows.

Every window, other than a fixed window, shall be easily openable and capable of being held in position by window hardware.

304.14 Insect screens.

During the period from April 15 to October 1, every door, window and other outside opening required for *ventilation* of habitable rooms, food preparation areas, food service areas or any areas where products to be included or utilized in food for human consumption are processed, manufactured, packaged or stored shall be supplied with *approved* tightly fitting screens of minimum 16 mesh per inch (16 mesh per 25 mm), and every screen door used for insect control shall have a self-closing device in good working condition.

Exception: Screens shall not be required where other *approved* means, such as air curtains or insect repellent fans, are employed.

304.15 Doors.

Exterior doors, door assemblies, operator systems if provided, and hardware shall be maintained in good condition. Locks at all entrances to dwelling units and sleeping units shall tightly secure the door. Locks on means of egress doors shall be in accordance with Section 702.3.

304.16 Basement hatchways.

Every *basement* hatchway shall be maintained to prevent the entrance of rodents, rain and surface drainage water.

304.17 Guards for basement windows.

Every *basement* window that is openable shall be supplied with rodent shields, storm windows or other *approved* protection against the entry of rodents.

304.18 Building security.

Doors, windows or hatchways for *dwelling units*, room units or *housekeeping units* shall be provided with devices designed to provide security for the *occupants* and property within.

304.18.1 Doors.

Doors providing access to a *dwelling unit*, *rooming unit* or *housekeeping unit* that is rented, leased or let shall be equipped with a deadbolt lock designed to be readily openable from the side from which egress is to be made without the need for keys, special knowledge or effort and shall have a minimum lock throw of 1 inch (25 mm). Such deadbolt locks shall be installed according to the manufacturer's specifications and maintained in good working order. For the purpose of this section, a sliding bolt shall not be considered an acceptable deadbolt lock.

304.18.2 Windows.

Operable windows located in whole or in part within 6 feet (1828 mm) above ground level or a walking surface below that provide access to a *dwelling unit*, *rooming unit* or *housekeeping unit* that is rented, leased or let shall be equipped with a window sash locking device.

304.18.3 Basement hatchways.

Basement hatchways that provide access to a *dwelling unit*, *rooming unit* or *housekeeping unit* that is rented, leased or let shall be equipped with devices that secure the units from unauthorized entry.

304.19 Gates.

Exterior gates, gate assemblies, operator systems if provided, and hardware shall be maintained in good condition. Latches at all entrances shall tightly secure the gates.

**SECTION 305
INTERIOR STRUCTURE**

305.1 General.

The interior of a structure and equipment therein shall be maintained in good repair, structurally sound and in a sanitary condition. *Occupants* shall keep that part of the structure that they occupy or control in a clean and sanitary condition. Every *owner* of a structure containing a *rooming house*, *housekeeping units*, a hotel, a dormitory, two or more *dwelling units* or two or more nonresidential occupancies, shall maintain, in a clean and sanitary condition, the shared or public areas of the structure and *exterior property*.

305.1.1 Unsafe conditions.

The following conditions shall be determined as unsafe and shall be repaired or replaced to

comply with the *International Building Code* or the *International Existing Building Code* as required for existing buildings:

1. The nominal strength of any structural member is exceeded by nominal loads, the load effects or the required strength;
2. The anchorage of the floor or roof to walls or columns, and of walls and columns to foundations is not capable of resisting all nominal loads or load effects;
3. Structures or components thereof that have reached their limit state;
4. Structural members are incapable of supporting nominal loads and load effects;
5. Stairs, landings, balconies and all similar walking surfaces, including *guards* and handrails, are not structurally sound, not properly *anchored* or are *anchored* with connections not capable of supporting all nominal loads and resisting all load effects;
6. Foundation systems that are not firmly supported by footings are not plumb and free from open cracks and breaks, are not properly *anchored* or are not capable of supporting all nominal loads and resisting all load effects.

Exceptions:

1. Where substantiated otherwise by an *approved* method.
2. Demolition of unsafe conditions shall be permitted when *approved* by the *code official*.

305.2 Structural members.

Structural members shall be maintained structurally sound, and be capable of supporting the imposed loads.

305.3 Interior surfaces.

Interior surfaces, including windows and doors, shall be maintained in good, clean and sanitary condition.

305.4 Stairs and walking surfaces.

Every stair, ramp, landing, balcony, porch, deck or other walking surface shall be maintained in sound condition and good repair.

305.5 Handrails and guards.

Every handrail and *guard* shall be firmly fastened and capable of supporting normally imposed loads and shall be maintained in good condition.

305.6 Interior doors.

Every interior door shall fit reasonably well within its frame and shall be capable of being opened and closed by being properly and securely attached to jambs, headers or tracks as intended by the manufacturer of the attachment hardware.

**SECTION 306
INTENTIONALLY LEFT BLANK**

**SECTION 307
HANDRAILS AND GUARDRAILS**

307.1 General.

Every exterior and interior flight of stairs having more than four risers shall have a handrail on one side of the stair and every open portion of a stair, landing, balcony, porch, deck, ramp or other walking surface that is more than 30 inches (762 mm) above the floor or grade below shall have *guards*. Handrails shall be not less than 30 inches (762 mm) in height or more than 42 inches (1067 mm) in height measured vertically above the nosing of the tread or above the finished floor of the landing or walking surfaces. *Guards* shall be not less than 30 inches (762 mm) in height above the floor of the landing, balcony, porch, deck, or ramp or other walking surface.

Exception: *Guards* shall not be required where exempted by the adopted building code.

**SECTION 308
RUBBISH AND GARBAGE**

308.1 Accumulation of rubbish or garbage.

Exterior property and premises, and the interior of every structure, shall be free from any accumulation of *rubbish* or garbage.

308.2 Disposal of rubbish.

Every *occupant* of a structure shall dispose of all *rubbish* in a clean and sanitary manner by placing such *rubbish* in *approved* containers.

308.2.1 Rubbish storage facilities.

The *owner* of every occupied *premises* shall supply *approved* covered containers for *rubbish*, and the *owner* of the *premises* shall be responsible for the removal of *rubbish*.

308.2.2 Refrigerators.

Refrigerators and similar equipment not in operation shall not be discarded, abandoned or stored on *premises* without first removing the doors.

308.3 Disposal of garbage.

Every *occupant* of a structure shall dispose of garbage in a clean and sanitary manner by placing such garbage in an *approved* garbage disposal facility or *approved* garbage containers.

308.3.1 Garbage facilities.

The *owner* of every dwelling shall supply one of the following: an *approved* mechanical food waste grinder in each *dwelling unit*; an *approved* incinerator unit in the structure available to the *occupants* in each *dwelling unit*; or an *approved* leakproof, covered, outside garbage container.

308.3.2 Containers.

The *operator* of every establishment producing garbage shall provide, and at all times cause to be utilized, *approved* leakproof containers provided with close-fitting covers for the storage of such materials until removed from the *premises* for disposal.

308.3.3 Storage, collection and removal.

The owner of every residential, commercial, institutional and industrial establishment shall ensure that all municipal waste from the premises is removed properly and in such a manner not to create a public nuisance.

Section 308.3.4 Recyclables.

The owner of any residential, commercial or industrial establishment shall be responsible for the proper storage, collection and disposal of all recyclables from the property and in such a manner not to create a public nuisance.

308.4 Solid Waste and Recyclable Ordinance.

Every owner of every dwelling shall comply with the Solid Waste and Recyclable Ordinance of the Township in effect regarding the removal of municipal waste from the property.

**SECTION 309
PEST ELIMINATION**

309.1 Infestation.

Structures shall be kept free from insect and rodent *infestation*. Structures in which insects or rodents are found shall be promptly exterminated by *approved* processes that will not be injurious to human health. After pest elimination, proper precautions shall be taken to prevent reinfestation.

309.2 Owner.

The *owner* of any structure shall be responsible for pest elimination within the structure prior to renting or leasing the structure.

309.3 Single occupant.

The *occupant* of a one-family dwelling or of a single-*tenant* nonresidential structure shall be responsible for pest elimination on the *premises*.

309.4 Multiple occupancy.

The *owner* of a structure containing two or more *dwelling units*, a multiple *occupancy*, a *rooming house* or a nonresidential structure shall be responsible for pest elimination in the public or shared areas of the structure and *exterior property*. If *infestation* is caused by failure of an *occupant* to prevent such *infestation* in the area occupied, the *occupant* and *owner* shall be responsible for pest elimination.

309.5 Occupant.

The *occupant* of any structure shall be responsible for the continued rodent and pest-free condition of the structure.

Exception: Where the *infestations* are caused by defects in the structure, the *owner* shall be responsible for pest elimination.

**SECTION 310
KITCHEN FACILITIES**

310.1 Kitchen stove.

The owner or operator of rental residential property shall provide every *dwelling unit* with utility connection for installed cooking appliance(s).

310.2 Kitchen sink.

The owner or operator of rental residential property shall provide every *dwelling unit* with a kitchen sink in good working condition which provides an adequate amount of heated and unheated running water under pressure.

310.3 Refrigerator.

The owner or operator of rental residential property shall provide every *dwelling unit* with a utility connection for refrigeration.

310.4 Counters and cabinets.

All counters, countertops and cabinets provided for cooking in a rental residential property shall be maintained in good repair.

CHAPTER 4

LIGHT, VENTILATION AND OCCUPANCY LIMITATIONS

SECTION 401 GENERAL

401.1 Scope.

The provisions of this chapter shall govern the minimum conditions and standards for light, *ventilation* and space for occupying a structure.

401.2 Responsibility.

The *owner* of the structure shall provide and maintain light, *ventilation* and space conditions in compliance with these requirements. A person shall not occupy as *owner-occupant*, or permit another person to occupy, any *premises* that do not comply with the requirements of this chapter.

401.3 Alternative devices.

In lieu of the means for natural light and *ventilation* herein prescribed, artificial light or mechanical *ventilation* complying with the *International Building Code* shall be permitted.

SECTION 402 LIGHT

402.1 Habitable spaces.

Every *habitable space* shall have not less than one window of *approved* size facing directly to the outdoors or to a court. The minimum total glazed area for every *habitable space* shall be 8 percent of the floor area of such room. Wherever walls or other portions of a structure face a window of any room and such obstructions are located less than 3 feet (914 mm) from the window and extend to a level above that of the ceiling of the room, such window shall not be deemed to face directly to the outdoors nor to a court and shall not be included as contributing to the required minimum total window area for the room.

Exception: Where natural light for rooms or spaces without exterior glazing areas is provided through an adjoining room, the unobstructed opening to the adjoining room shall be not less than 8 percent of the floor area of the interior room or space, but a minimum of 25 square feet (2.33 m²). The exterior glazing area shall be based on the total floor area being served.

402.2 Common halls and stairways.

Every common hall and stairway in residential occupancies, other than in one- and two-family dwellings, shall be lighted at all times with not less than a 60-watt standard incandescent light bulb for each 200 square feet (19 m²) of floor area or equivalent illumination, provided that the spacing between lights shall not be greater than 30 feet (9144 mm). In other than residential occupancies, means of egress, including exterior means of egress, stairways shall be illuminated at all times the building space served by the means of egress is occupied with not less than 1 footcandle (11 lux) at floors, landings and treads.

402.3 Other spaces.

All other spaces shall be provided with natural or artificial light sufficient to permit the maintenance of sanitary conditions, and the safe *occupancy* of the space and utilization of the appliances, equipment and fixtures.

SECTION 403 VENTILATION

403.1 Habitable spaces.

Every *habitable space* shall have not less than one openable window. The total openable area of the window in every room shall be equal to not less than 45 percent of the minimum glazed area required in Section 402.1.

Exception: Where rooms and spaces without openings to the outdoors are ventilated through an adjoining room, the unobstructed opening to the adjoining room shall be not less than 8 percent of the floor area of the interior room or space, but not less than 25 square feet (2.33 m²). The *ventilation* openings to the outdoors shall be based on a total floor area being ventilated.

403.2 Bathrooms and toilet rooms.

Every *bathroom* and *toilet room* shall comply with the *ventilation* requirements for *habitable spaces* as required by Section 403.1, except that a window shall not be required in such spaces equipped with a mechanical *ventilation* system. Air exhausted by a mechanical *ventilation* system from a *bathroom* or *toilet room* shall discharge to the outdoors and shall not be recirculated.

403.3 Cooking facilities.

Unless *approved* through the certificate of *occupancy*, cooking shall not be permitted in any *rooming unit* or dormitory unit, and a cooking facility or appliance shall not be permitted to be present in the *rooming unit* or dormitory unit.

Exceptions:

1. Where specifically *approved* in writing by the *code official*.
2. Devices such as coffee pots and microwave ovens shall not be considered cooking appliances.

403.4 Process ventilation.

Where injurious, toxic, irritating or noxious fumes, gases, dusts or mists are generated, a local exhaust *ventilation* system shall be provided to remove the contaminating agent at the source. Air shall be exhausted to the exterior and not be recirculated to any space.

403.5 Clothes dryer exhaust.

Clothes dryer exhaust systems shall be independent of all other systems and shall be exhausted outside the structure in accordance with the manufacturer's instructions.

Exception: Listed and *labeled* condensing (ductless) clothes dryers.

SECTION 404 OCCUPANCY LIMITATIONS

404.1 Privacy.

Dwelling units, hotel units, *housekeeping units*, *rooming units* and dormitory units shall be arranged to provide privacy and be separate from other adjoining spaces.

404.2 Minimum room widths.

A habitable room, other than a kitchen, shall be not less than 7 feet (2134 mm) in any plan dimension. Kitchens shall have a minimum clear passageway of 3 feet (914 mm) between counterfronts and appliances or counterfronts and walls.

404.3 Minimum ceiling heights.

Habitable spaces, hallways, corridors, laundry areas, *bathrooms*, *toilet rooms* and habitable *basement* areas shall have a minimum clear ceiling height of 7 feet (2134 mm).

Exceptions:

1. In one- and two-family dwellings, beams or girders spaced not less than 4 feet (1219 mm) on center and projecting a maximum of 6 inches (152 mm) below the required ceiling height.
2. *Basement* rooms in one- and two-family dwellings occupied exclusively for laundry, study or recreation purposes, having a minimum ceiling height of 6 feet 8 inches (2033 mm) with a minimum clear height of 6 feet 4 inches (1932 mm) under beams, girders, ducts and similar obstructions.
3. Rooms occupied exclusively for sleeping, study or similar purposes and having a sloped ceiling over all or part of the room, with a minimum clear ceiling height of 7 feet (2134 mm) over not less than one-third of the required minimum floor area. In calculating the floor area of such rooms, only those portions of the floor area with a minimum clear ceiling height of 5 feet (1524 mm) shall be included.

404.4 Bedroom and living room requirements.

Every *bedroom* and living room shall comply with the requirements of Sections 404.4.1 through 404.4.5.

404.4.1 Room area.

Every living room shall contain not less than 120 square feet (11.2 m²) and every bedroom shall contain not less than 70 square feet (6.5 m²) and every bedroom occupied by more than one person shall contain not less than 50 square feet (4.6 m²) of floor area for each occupant thereof.

404.4.2 Access from bedrooms.

Bedrooms shall not constitute the only means of access to other *bedrooms* or *habitable spaces* and shall not serve as the only means of egress from other *habitable spaces*.

Exception: Units that contain fewer than two *bedrooms*.

404.4.3 Water closet accessibility.

Every *bedroom* shall have access to not less than one water closet and one lavatory without passing through another *bedroom*. Every *bedroom* in a *dwelling unit* shall have access to not less than one water closet and lavatory located in the same story as the *bedroom* or an adjacent story.

404.4.4 Prohibited occupancy.

Kitchens and nonhabitable spaces shall not be used for sleeping purposes.

404.4.5 Other requirements.

Bedrooms shall comply with the applicable provisions of this code including, but not limited to, the light, *ventilation*, room area, ceiling height and room width requirements of this chapter; the plumbing facilities and water-heating facilities requirements of Chapter 5; the heating facilities and electrical receptacle requirements of Chapter 6; and the smoke detector and emergency escape requirements of Chapter 7.

404.5 Overcrowding.

Dwelling units shall not be occupied by more occupants than permitted by the minimum area requirements of Table 404.5.

**TABLE 404.5
MINIMUM AREA REQUIREMENTS**

SPACE	MINIMUM AREA IN SQUARE FEET		
	1-2 occupants	3-5 occupants	6 or more occupants
Living room ^{a, b}	120	120	150
Dining room ^{a, b}	No requirement	80	100
Bedrooms	Shall comply with Section 404.4.1		

For SI: 1 square foot = 0.0929 m².

- a. See Section 404.5.2 for combined living room/dining room spaces.
- b. See Section 404.5.1 for limitations on determining the minimum occupancy area for sleeping purposes.

404.5.1 Sleeping area.

The minimum occupancy area required by Table 404.5 shall not be included as a sleeping area in determining the minimum occupancy area for sleeping purposes. Sleeping areas shall comply with Section 404.4.

404.5.2 Combined spaces.

Combined living room and dining room spaces shall comply with the requirements of Table 404.5 if the total area is equal to that required for separate rooms and if the space is located so as to function as a combination living room/dining room.

404.6 Efficiency unit.

Nothing in this section shall prohibit an efficiency living unit from meeting the following requirements:

1. A unit occupied by not more than one occupant shall have a minimum clear floor area of 120 square feet (11.2 m²). A unit occupied by not more than two *occupants* shall have a minimum clear floor area of 220 square feet (20.4 m²). A unit occupied by three *occupants* shall have a minimum clear floor area of 320 square feet (29.7 m²). These required areas shall be exclusive of the areas required by Items 2 and 3.
2. The unit shall be provided with a kitchen sink, cooking appliance and refrigeration facilities, each having a minimum clear working space of 30 inches (762 mm) in front. Light and *ventilation* conforming to this code shall be provided.
3. The unit shall be provided with a separate *bathroom* containing a water closet, lavatory and bathtub or shower.
4. The maximum number of *occupants* shall be three.

404.7 Food preparation.

All spaces to be occupied for food preparation purposes shall contain suitable space and equipment to store, prepare and serve foods in a sanitary manner. There shall be adequate facilities and services for the sanitary disposal of food wastes and refuse, including facilities for temporary storage.

CHAPTER 5 PLUMBING FACILITIES AND FIXTURE REQUIREMENTS

SECTION 501 GENERAL

501.1 Scope.

The provisions of this chapter shall govern the minimum plumbing systems, facilities and plumbing fixtures to be provided.

501.2 Responsibility.

The *owner* of the structure shall provide and maintain such plumbing facilities and plumbing fixtures in compliance with these requirements. A person shall not occupy as *owner-occupant* or permit another person to occupy any structure or *premises* that does not comply with the requirements of this chapter.

SECTION 502 REQUIRED FACILITIES

502.1 Dwelling units.

Every *dwelling unit* shall contain its own bathtub or shower, lavatory, water closet and kitchen sink that shall be maintained in a sanitary, safe working condition. The lavatory shall be placed in the same room as the water closet or located in close proximity to the door leading directly into the room in which such water closet is located. A kitchen sink shall not be used as a substitute for the required lavatory.

502.2 Rooming houses.

Not less than one water closet, lavatory and bathtub or shower shall be supplied for each four *rooming units*.

502.3 Hotels.

Where private water closets, lavatories and baths are not provided, one water closet, one lavatory and one bathtub or shower having access from a public hallway shall be provided for each 10 *occupants*.

502.4 Employees' facilities.

Not less than one water closet, one lavatory and one drinking facility shall be available to employees.

502.4.1 Drinking facilities.

Drinking facilities shall be a drinking fountain, water cooler, bottled water cooler or disposable cups next to a sink or water dispenser. Drinking facilities shall not be located in *toilet rooms* or *bathrooms*.

502.5 Public toilet facilities.

Public toilet facilities shall be maintained in a safe, sanitary and working condition in accordance

with the *International Plumbing Code*. Except for periodic maintenance or cleaning, public access and use shall be provided to the toilet facilities at all times during *occupancy* of the *premises*.

SECTION 503 TOILET ROOMS

503.1 Privacy.

Toilet rooms and *bathrooms* shall provide privacy and shall not constitute the only passageway to a hall or other space, or to the exterior. A door and interior locking device shall be provided for all common or shared *bathrooms* and *toilet rooms* in a multiple dwelling.

503.2 Location.

Toilet rooms and *bathrooms* serving hotel units, *rooming units* or dormitory units or *housekeeping units*, shall have access by traversing not more than one flight of stairs and shall have access from a common hall or passageway.

503.3 Location of employee toilet facilities.

Toilet facilities shall have access from within the employees' working area. The required toilet facilities shall be located not more than one story above or below the employees' working area and the path of travel to such facilities shall not exceed a distance of 500 feet (152 m). Employee facilities shall either be separate facilities or combined employee and public facilities.

Exception: Facilities that are required for employees in storage structures or kiosks, which are located in adjacent structures under the same ownership, lease or control, shall not exceed a travel distance of 500 feet (152 m) from the employees' regular working area to the facilities.

503.4 Floor surface.

In other than *dwelling units*, every *toilet room* floor shall be maintained to be a smooth, hard, nonabsorbent surface to permit such floor to be easily kept in a clean and sanitary condition.

SECTION 504 PLUMBING SYSTEMS AND FIXTURES

504.1 General.

Plumbing fixtures shall be properly installed and maintained in working order, and shall be kept free from obstructions, leaks and defects and be capable of performing the function for which such plumbing fixtures are designed. Plumbing fixtures shall be maintained in a safe, sanitary and functional condition. Floor drains in existing residential and non-residential structures shall discharge by means of gravity, or an approved sump pump with a sealed lid, to the exterior of the structure. Floor drains shall not be connected to the sanitary sewer system. Piping materials and fittings used for discharge shall conform to the underground building drainage requirements in the adopted International Residential Code. Floor drain piping discharge termination shall be at least 5 feet from the exterior foundation wall and discharge in a manner that does not create a nuisance on the adjacent property(s), and shall terminate no closer than 10 feet from the street right-of-way.

504.2 Fixture clearances.

Plumbing fixtures shall have adequate clearances for usage and cleaning.

504.3 Plumbing system hazards.

Where it is found that a plumbing system in a structure constitutes a hazard to the *occupants* or the structure by reason of inadequate service, inadequate venting, cross connection, back-siphonage, improper installation, *deterioration* or damage or for similar reasons, the *code official* shall require the defects to be corrected to eliminate the hazard.

**SECTION 505
WATER SYSTEM**

505.1 General.

Every sink, lavatory, bathtub or shower, drinking fountain, water closet or other plumbing fixture shall be properly connected to either a public water system or to an *approved* private water system. Kitchen sinks, lavatories, laundry facilities, bathtubs and showers shall be supplied with hot or tempered and cold running water in accordance with the *International Plumbing Code*.

505.2 Contamination.

The water supply shall be maintained free from contamination, and all water inlets for plumbing fixtures shall be located above the flood-level rim of the fixture. Shampoo basin faucets, janitor sink faucets and other hose bibs or faucets to which hoses are attached and left in place, shall be protected by an approved atmospheric-type vacuum breaker or an approved permanently attached hose connection vacuum breaker.

505.3 Supply.

The water supply system shall be installed and maintained to provide a supply of water to plumbing fixtures, devices and appurtenances in sufficient volume and at pressures adequate to enable the fixtures to function properly, safely, and free from defects and leaks.

505.4 Water heating facilities.

Water heating facilities shall be properly installed, maintained and capable of providing an adequate amount of water to be drawn at every required sink, lavatory, bathtub, shower and laundry facility at a minimum temperature of 110°F (43°C). A gas-burning water heater shall not be located in any *bathroom, toilet room, bedroom* or other occupied room normally kept closed, unless adequate combustion air is provided. An *approved* combination temperature and pressure-relief valve and relief valve discharge pipe shall be properly installed and maintained on water heaters.

**SECTION 506
SANITARY DRAINAGE SYSTEM**

506.1 General.

Plumbing fixtures shall be properly connected to either a public sewer system or to an *approved* private sewage disposal system. Existing on-lot (private) sewage facilities shall comply with the Pennsylvania Code, Title 25, Chapter 71 and the Manheim Township Code of Ordinances, Chapter 399 Sewers and Sewage Disposal.

In existing structures with on-lot sewage systems an inspection, performed by an approved

septic service company in accordance with the current Manheim Township Administrative Order, shall evaluate and verify that the on-lot sewage facility(s) properly operates in accordance with Manheim Township Code of Ordinances, Chapter 399 Sewers and Sewage Disposal regulations prior to the issuance of any permit. Provisions shall be made for additional flows when bedrooms are added or as other conditions warrant. Noted deficiencies shall be corrected under a permit issued by the Manheim Township Sewage Enforcement Officer.

506.2 Maintenance.

Every plumbing stack, vent, waste and sewer line shall function properly and be kept free from obstructions, leaks and defects.

506.3 Grease interceptors.

Grease interceptors and automatic grease removal devices shall be maintained in accordance with this code and the manufacturer's installation instructions. Grease interceptors and automatic grease removal devices shall be regularly serviced and cleaned to prevent the discharge of oil, grease, and other substances harmful or hazardous to the building drainage system, the public sewer, the private sewage disposal system or the sewage treatment plant or processes. Records of maintenance, cleaning and repairs shall be available for inspection by the code official.

506.4 Sump pump discharge.

Sump pumps discharging groundwater shall not connect to the sanitary sewer, unless approved by the sewer authority having jurisdiction. The sump pit shall be an approved type with a sealed lid.

**SECTION 507
STORM DRAINAGE**

507.1 Roof Drainage.

The controlled method of water disposal from roofs shall terminate at least 5 feet beyond the exterior foundation wall and discharge in a manner that does not create a nuisance on the adjacent property(s) and shall terminate no closer than 10 feet from the street right-of-way.

507.2 Sump pump discharge.

Sump pump pipes discharging groundwater shall terminate at least 5 feet beyond the exterior foundation wall and discharge in a manner that does not create a nuisance on the adjacent property(s), but no closer than 10 feet from the street right-of-way.

CHAPTER 6

MECHANICAL AND ELECTRICAL REQUIREMENTS

SECTION 601 GENERAL

601.1 Scope.

The provisions of this chapter shall govern the minimum mechanical and electrical facilities and equipment to be provided.

601.2 Responsibility.

The *owner* of the structure shall provide and maintain mechanical and electrical facilities and equipment in compliance with these requirements. A person shall not occupy as *owner-occupant* or permit another person to occupy any *premises* that does not comply with the requirements of this chapter.

SECTION 602 HEATING FACILITIES

602.1 Facilities required.

Permanent heating facilities shall be provided in structures as required by this section.

602.2 Residential occupancies.

Dwellings shall be provided with heating facilities capable of maintaining a room temperature of 68°F (20°C) in all habitable rooms, *bathrooms* and *toilet rooms* based on the winter outdoor design temperature for the locality indicated in Appendix D of the *International Plumbing Code*. Cooking appliances shall not be used, nor shall portable unvented fuel-burning space heaters be used, as a means to provide required heating.

Exception: In areas where the average monthly temperature is above 30°F (-1°C), a minimum temperature of 65°F (18°C) shall be maintained.

602.3 Heat supply.

Every *owner* and *operator* of any building who rents, leases or lets one or more *dwelling units* or *sleeping units* on terms, either expressed or implied, to furnish heat to the *occupants* thereof shall supply heat during the period from October 1 to April 15 to maintain a minimum temperature of 68°F (20°C) in all habitable rooms, *bathrooms* and *toilet rooms*.

Exceptions:

1. When the outdoor temperature is below the winter outdoor design temperature for the locality, maintenance of the minimum room temperature shall not be required provided that the heating system is operating at its full design capacity. The winter outdoor design temperature for the locality shall be as indicated in Appendix D of the *International Plumbing Code*.
2. In areas where the average monthly temperature is above 30°F (-1°C), a minimum temperature of 65°F (18°C) shall be maintained.

602.4 Occupiable work spaces.

Indoor occupiable work spaces shall be supplied with heat during the period from October 1 to April 15 to maintain a minimum temperature of 65°F (18°C) during the period the spaces are occupied.

Exceptions:

1. Processing, storage and operation areas that require cooling or special temperature conditions.
2. Areas in which persons are primarily engaged in vigorous physical activities.

602.5 Room temperature measurement.

The required room temperatures shall be measured 3 feet (914 mm) above the floor near the center of the room and 2 feet (610 mm) inward from the center of each exterior wall.

Section 602.6 Prohibited method of heating.

Liquid-gas-type portable heating appliances shall be prohibited except in single-family residential homes. Wood-burning stoves are prohibited except in single-family residential owner-occupied homes.

**SECTION 603
MECHANICAL EQUIPMENT**

603.1 Mechanical appliances.

Mechanical appliances, fireplaces, solid fuel-burning appliances, cooking appliances and water heating appliances shall be properly installed and maintained in a safe working condition, and shall be capable of performing the intended function.

603.2 Removal of combustion products.

Fuel-burning equipment and appliances shall be connected to an *approved* chimney or vent.

Exception: Fuel-burning equipment and appliances that are *labeled* for unvented operation.

603.3 Clearances.

Required clearances to combustible materials shall be maintained.

603.4 Safety controls.

Safety controls for fuel-burning equipment shall be maintained in effective operation.

603.5 Combustion air.

A supply of air for complete combustion of the fuel and for *ventilation* of the space containing the fuel-burning equipment shall be provided for the fuel-burning equipment.

603.6 Energy conservation devices.

Devices intended to reduce fuel consumption by attachment to a fuel-burning appliance, to the

fuel supply line thereto, or to the vent outlet or vent piping therefrom, shall not be installed unless *labeled* for such purpose and the installation is specifically *approved*.

SECTION 604 ELECTRICAL FACILITIES

604.1 Facilities required.

Every occupied building shall be provided with an electrical system in compliance with the requirements of this section and Section 605.

604.2 Service.

The size and usage of appliances and equipment shall serve as a basis for determining the need for additional facilities in accordance with NFPA 70. *Dwelling units* shall be served by a three-wire, 120/240 volt, single-phase electrical service having a minimum rating of 60 amperes.

604.3 Electrical system hazards.

Where it is found that the electrical system in a structure constitutes a hazard to the *occupants* or the structure by reason of inadequate service, improper fusing, insufficient receptacle and lighting outlets, improper wiring or installation, *deterioration* or damage, or for similar reasons, the *code official* shall require the defects to be corrected to eliminate the hazard.

604.3.1 Abatement of electrical hazards associated with water exposure.

The provisions of this section shall govern the repair and replacement of electrical systems and equipment that have been exposed to water.

604.3.1.1 Electrical equipment.

Electrical distribution equipment, motor circuits, power equipment, transformers, wire, cable, flexible cords, wiring devices, ground fault circuit interrupters, surge protectors, molded case circuit breakers, low-voltage fuses, luminaires, ballasts, motors and electronic control, signaling and communication equipment that have been exposed to water shall be replaced in accordance with the provisions of the *International Building Code*.

Exception: The following equipment shall be allowed to be repaired where an inspection report from the equipment manufacturer or *approved* manufacturer's representative indicates that the equipment has not sustained damage that requires replacement:

1. Enclosed switches, rated a maximum of 600 volts or less;
2. Busway, rated a maximum of 600 volts;
3. Panelboards, rated a maximum of 600 volts;
4. Switchboards, rated a maximum of 600 volts;
5. Fire pump controllers, rated a maximum of 600 volts;
6. Manual and magnetic motor controllers;

7. Motor control centers;
8. Alternating current high-voltage circuit breakers;
9. Low-voltage power circuit breakers;
10. Protective relays, meters and current transformers;
11. Low- and medium-voltage switchgear;
12. Liquid-filled transformers;
13. Cast-resin transformers;
14. Wire or cable that is suitable for wet locations and whose ends have not been exposed to water;
15. Wire or cable, not containing fillers, that is suitable for wet locations and whose ends have not been exposed to water;
16. Luminaires that are listed as submersible;
17. Motors;
18. Electronic control, signaling and communication equipment.

604.3.2 Abatement of electrical hazards associated with fire exposure.

The provisions of this section shall govern the repair and replacement of electrical systems and equipment that have been exposed to fire.

604.3.2.1 Electrical equipment.

Electrical switches, receptacles and fixtures, including furnace, water heating, security system and power distribution circuits, that have been exposed to fire, shall be replaced in accordance with the provisions of the *International Building Code*.

Exception: Electrical switches, receptacles and fixtures that shall be allowed to be repaired where an inspection report from the equipment manufacturer or *approved* manufacturer's representative indicates that the equipment has not sustained damage that requires replacement.

SECTION 605 ELECTRICAL EQUIPMENT

605.1 Installation.

Electrical equipment, wiring and appliances shall be properly installed and maintained in a safe and *approved* manner.

605.2 Receptacles.

Every *habitable space* in a dwelling shall contain not less than two separate and remote receptacle outlets. Every laundry area shall contain not less than one grounding-type receptacle

or a receptacle with a ground fault circuit interrupter. Every *bathroom* shall contain not less than one receptacle. Any new *bathroom* receptacle outlet shall have ground fault circuit interrupter protection. All receptacle outlets shall have the appropriate faceplate cover for the location.

605.3 Luminaires.

Every public hall, interior stairway, *toilet room*, kitchen, *bathroom*, laundry room, boiler room and furnace room shall contain not less than one electric luminaire. Pool and spa luminaires over 15 V shall have ground fault circuit interrupter protection.

605.4 Wiring.

Flexible cords shall not be used for permanent wiring, or for running through doors, windows, or cabinets, or concealed within walls, floors, or ceilings.

**SECTION 606
ELEVATORS, ESCALATORS AND DUMBWAITERS**

606.1 General.

All requirements relating to elevators and other lifting devices shall be administered and enforced by the PA Department of Labor and Industry Elevator Division in accordance with the applicable edition of ASME A.17.1 and any addenda.

606.2 Elevators.

In buildings equipped with passenger elevators, not less than one elevator shall be maintained in operation at all times when the building is occupied.

Exception: Buildings equipped with only one elevator shall be permitted to have the elevator temporarily out of service for testing or servicing.

**SECTION 607
DUCT SYSTEMS**

607.1 General.

Duct systems shall be maintained free of obstructions and shall be capable of performing the required function.

CHAPTER 7 FIRE SAFETY REQUIREMENTS

SECTION 701 GENERAL

701.1 Scope.

The provisions of this chapter shall govern the minimum conditions and standards for fire safety relating to structures and exterior *premises*, including fire safety facilities and equipment to be provided.

701.2 Responsibility.

The *owner* of the *premises* shall provide and maintain such fire safety facilities and equipment in compliance with these requirements. A person shall not occupy as *owner-occupant* or permit another person to occupy any *premises* that do not comply with the requirements of this chapter.

701.3 Applicability of International Fire Code.

Applicability of International Fire Code. The International Fire Code shall be applied to provide minimum requirements consistent with nationally recognized good practice for providing a reasonable level of life safety and property protection from the hazards of fire, explosion or dangerous conditions in existing buildings, structures and premises and to provide safety to building occupants, fire fighters and emergency responders during emergency operations.

SECTION 702 MEANS OF EGRESS

702.1 General.

A safe, continuous and unobstructed path of travel shall be provided from any point in a building or structure to the *public way*. Means of egress shall comply with the *International Fire Code*.

702.2 Aisles.

The required width of aisles in accordance with the *International Fire Code* shall be unobstructed.

702.3 Locked doors.

Means of egress doors shall be readily openable from the side from which egress is to be made without the need for keys, special knowledge or effort, except where the door hardware conforms to that permitted by the *International Building Code*.

702.4 Emergency escape openings.

Required emergency escape openings shall be maintained in accordance with the code in effect at the time of construction, and the following. Required emergency escape and rescue openings shall be operational from the inside of the room without the use of keys or tools. Bars, grilles, grates or similar devices are permitted to be placed over emergency escape and rescue openings provided the minimum net clear opening size complies with the code that was in effect at the time of construction and such devices shall be releasable or removable from the inside

without the use of a key, tool or force greater than that which is required for normal operation of the escape and rescue opening.

SECTION 703 FIRE-RESISTANCE RATINGS

703.1 Fire-resistance-rated assemblies.

The required fire-resistance rating of fire-resistance-rated walls, fire stops, shaft enclosures, partitions and floors shall be maintained.

703.2 Opening protectives.

Required opening protectives shall be maintained in an operative condition. Fire and smokestop doors shall be maintained in operable condition. Fire doors and smoke barrier doors shall not be blocked or obstructed or otherwise made inoperable.

703.3 Fire sprinkler area.

Existing building area currently protected by automatic fire sprinkler systems shall be separated from an adjacent building area which is not protected by a fire sprinkler system by constructing an approved 2-hour fire-resistive rated fire barrier assembly(ies) and/or horizontal assembly(ies) in accordance with the Fire Barrier requirements in the currently adopted International Building Code. More restrictive requirements shall apply as required by the International Building Code.

SECTION 704 FIRE PROTECTION SYSTEMS

704.1 General.

Systems, devices and equipment to detect a fire, actuate an alarm, or suppress or control a fire or any combination thereof shall be inspected, tested and maintained in an operable condition at all times in accordance with the *International Fire Code*.

704.1.1 Automatic sprinkler systems.

Inspection, testing and maintenance of automatic sprinkler systems shall be in accordance with NFPA 25.

704.1.2 Fire department connection.

Where the fire department connection is not visible to approaching fire apparatus, the fire department connection shall be indicated by an *approved* sign mounted on the street front or on the side of the building. Such sign shall have the letters "FDC" not less than 6 inches (152 mm) high and words in letters not less than 2 inches (51 mm) high or an arrow to indicate the location. Such signs shall be subject to the approval of the fire code official.

704.2 Single- and multiple-station smoke alarms.

Single- and multiple-station smoke alarms shall be installed in existing Group I-1 and R occupancies in accordance with Sections 704.2.1 through 704.2.3.

704.2.1 Where required.

Existing Group I-1 and R occupancies shall be provided with single-station smoke alarms in accordance with Sections 704.2.1.1 through 704.2.1.4. Interconnection and power sources shall be in accordance with Sections 704.2.2 and 704.2.3.

Exceptions:

1. Where the code that was in effect at the time of construction required smoke alarms and smoke alarms complying with those requirements are already provided.
2. Where smoke alarms have been installed in occupancies and dwellings that were not required to have them at the time of construction, additional smoke alarms shall not be required provided that the existing smoke alarms comply with requirements that were in effect at the time of installation.
3. Where smoke detectors connected to a fire alarm system have been installed as a substitute for smoke alarms.

704.2.1.1 Group R-1.

Single- or multiple-station smoke alarms shall be installed in all of the following locations in Group R-1:

1. In sleeping areas.
2. In every room in the path of the *means of egress* from the sleeping area to the door leading from the *sleeping unit*.
3. In each story within the *sleeping unit*, including basements. For *sleeping units* with split levels and without an intervening door between the adjacent levels, a smoke alarm installed on the upper level shall suffice for the adjacent lower level provided that the lower level is less than one full story below the upper level.

704.2.1.2 Groups R-2, R-3, R-4 and I-1.

Single- or multiple-station smoke alarms shall be installed and maintained in Groups R-2, R-3, R-4 and I-1 regardless of *occupant load* at all of the following locations:

1. On the ceiling or wall outside of each separate sleeping area in the immediate vicinity of bedrooms.
2. In each room used for sleeping purposes.
3. In each story within a *dwelling unit*, including *basements* but not including crawl spaces and uninhabitable attics. In *dwellings* or *dwelling units* with split levels and without an intervening door between the adjacent levels, a smoke alarm installed on the upper level shall suffice for the adjacent lower level provided that the lower level is less than one full story below the upper level.

704.2.1.3 Installation near cooking appliances.

Smoke alarms shall not be installed in the following locations unless this would prevent placement of a smoke alarm in a location required by Section 704.2.1.1 or 704.2.1.2.

1. Ionization smoke alarms shall not be installed less than 20 feet (6096 m) horizontally from a permanently installed cooking appliance.

2. Ionization smoke alarms with an alarm-silencing switch shall not be installed less than 10 feet (3048 mm) horizontally from a permanently installed cooking appliance.
3. Photoelectric smoke alarms shall not be installed less than 6 feet (1829 mm) horizontally from a permanently installed cooking appliance.

704.2.1.4 Installation near bathrooms.

Smoke alarms shall be installed not less than 3 feet (914 mm) horizontally from the door or opening of a bathroom that contains a bathtub or shower unless this would prevent placement of a smoke alarm required by Section 704.2.1.1 or 704.2.1.2.

704.2.2 Interconnection.

Where more than one smoke alarm is required to be installed within an individual *dwelling* or *sleeping unit*, the smoke alarms shall be interconnected in such a manner that the activation of one alarm will activate all of the alarms in the individual unit. Physical interconnection of smoke alarms shall not be required where listed wireless alarms are installed and all alarms sound upon activation of one alarm. The alarm shall be clearly audible in all bedrooms over background noise levels with all intervening doors closed.

Exceptions:

1. Interconnection is not required in buildings that are not undergoing *alterations*, repairs or construction of any kind.
2. Smoke alarms in existing areas are not required to be interconnected where *alterations* or repairs do not result in the removal of interior wall or ceiling finishes exposing the structure, unless there is an attic, crawl space or basement available that could provide access for interconnection without the removal of interior finishes.

704.2.3 Power source.

Single-station smoke alarms shall receive their primary power from the building wiring provided that such wiring is served from a commercial source and shall be equipped with a battery backup. Smoke alarms with integral strobes that are not equipped with battery backup shall be connected to an emergency electrical system. Smoke alarms shall emit a signal when the batteries are low. Wiring shall be permanent and without a disconnecting switch other than as required for over-current protection.

Exceptions:

1. Smoke alarms are permitted to be solely battery operated in existing buildings where no construction is taking place.
2. Smoke alarms are permitted to be solely battery operated in buildings that are not served from a commercial power source.
3. Smoke alarms are permitted to be solely battery operated in existing areas of buildings undergoing *alterations* or repairs that do not result in the removal of interior walls or ceiling finishes exposing the structure, unless there is an attic,

crawl space or *basement* available that could provide access for building wiring without the removal of interior finishes.

704.2.4 Smoke detection system.

Smoke detectors listed in accordance with UL 268 and provided as part of the building's fire alarm system shall be an acceptable alternative to single- and multiple-station smoke alarms and shall comply with the following:

1. The fire alarm system shall comply with all applicable requirements in Section 907 of the *International Fire Code*.
2. Activation of a smoke detector in a dwelling or sleeping unit shall initiate alarm notification in the *dwelling* or *sleeping unit* in accordance with Section 907.5.2 of the *International Fire Code*.
3. Activation of a smoke detector in a *dwelling* or *sleeping unit* shall not activate alarm notification appliances outside of the *dwelling* or *sleeping unit*, provided that a supervisory signal is generated and monitored in accordance with Section 907.6.5 of the *International Fire Code*.

704.2.5 Tampering.

Anyone tampering or interfering with the effectiveness of a smoke detector shall be in violation of this code.

704.2.6 Maintenance.

The property owner shall maintain all smoke detectors located in rental units.

CHAPTER 8 REFERENCED STANDARDS

This chapter lists the standards that are referenced in various sections of this document. The standards are listed herein by the promulgating agency of the standard, the standard identification, the effective date and title and the section or sections of this document that reference the standard. The application of the referenced standards shall be as specified in Section 102.7.

ASME American Society of Mechanical Engineers
Three Park Avenue
New York, NY 10016-5990

Standard reference number	Title	Referenced in code section number
ASME A17.1/CSA B44—2013	Safety Code for Elevators and Escalators	606.1

ASTM ASTM International
100 Barr Harbor Drive
West Conshohocken, PA 19428-2959

Standard reference number	Title	Referenced in code section number
F 1346—91 (2010)	Performance Specifications for Safety Covers and Labeling Requirements for All Covers for Swimming Pools, Spas and Hot Tubs	303.2

ICC International Code Council
500 New Jersey Avenue, NW
6th Floor
Washington, DC 20001

Standard reference number	Title	Referenced in code section number
IBC—15	International Building Code [®]	102.3, 201.3, 304.1.1, 305.1.1, 306.1.1, 401.3, 702.3
IEBC—15	International Existing Building Code [®]	102.3, 305.1.1, 306.1.1
IFC—15	International Fire Code [®]	102.3, 201.3, 604.3.1.1, 604.3.2.1, 702.1, 702.2, 704.1, 704.2

IFGC—15	International Fuel Gas Code [®]	102.3
IMC—15	International Mechanical Code [®]	102.3, 201.3
IPC—15	International Plumbing Code [®]	102.3, 201.3, 505.1, 602.2, 602.3
IRC—15	International Residential Code [®]	102.3, 201.3

NFPA

National Fire Protection Association
 1 Batterymarch Park
 Quincy, MA 02269

Standard reference number	Title	Referenced in code section number
25—14	Standard for the Inspection, Testing and Maintenance of Water-Based Fire Protection Systems	704.1.1
70—14	National Electrical Code	102.4, 201.3, 604.2

INDEX

A

ACCESS

- Emergency egress 702
- From bedrooms 404.4.2
- Plumbing fixtures, access for cleaning 504.2
- To public way 702.1
- Toilet room as passageway 503.1
- Water closet 404.4.3

ADJACENT

- Privacy (hotel units, rooming units). 404.1

ADMINISTRATION

- Scope 101.2

AGENT (See also OPERATOR, OWNER)

- Definition. 202

AIR

- Combustion air 603.5

AISLES

- Minimum width 702.2

ALTERATION

- Applicability of other codes. 102.3
- Inspection 104.2
- Prosecution. 106.3
- Unlawful acts 106.1

ANCHOR

- Anchored, definition 202
- Architectural trim. 304.8
- Signs, marquees and awnings 304.9
- Unsafe conditions 304.1.1

APPEAL

- Application 111.1
- Board decision 111.6
- Board of appeals 111.2
- Court review 111.6
- Hearing, emergency orders 109.6
- Notice of appeal 111.1
- Postponed hearing 111.4
- Records 104.6
- Right to appeal 111.1

APPLIANCE

- Cooking 403.3, 602.2
- Mechanical 603.1

APPLICABILITY

- Application of references 102.9
- General 102.1
- Other laws. 102.10
- Referenced codes and standards. 102.7

APPROVAL

- Alternatives 105.2
- Authority 104.1
- Modifications. 105.1
- Research reports 105.6
- Used material and equipment 105.4

APPROVED

- Alternative materials, methods and equipment 105.2
- Definition. 202
- Energy conservation devices 603.6
- Garbage storage facilities 308.3.1
- Modifications. 105.1
- Used materials and equipment 105.4

ARTIFICIAL

- Lighting of habitable rooms. 402.1
- Lighting of other spaces 402.3

AUTOMOBILE

- Motor vehicles. 302.8

AWNING

- Signs, marquees and awnings 304.9

B

BALCONY

- Handrails and guardrails 304.12

BASEMENT

- Definition. 202
- Hatchways 304.16
- Windows 304.17

BATHROOM

- Common bathrooms 502.3, 503.1
- Hotels 502.3
- Lighting 605.3
- Locks. 503.1

Outlets required	605.2
Privacy	503.1
Ventilation	403.2

BATHTUB

Dwelling units	502.1
Rooming houses.	502.2
Sewage system.	506.1
Water-heating facilities	505.4
Water system	505.1

BOILER

Unsafe equipment	108.1.2
----------------------------	---------

C

CAPACITY

Heating facilities.	602.2, 602.3, 602.4
-----------------------------	---------------------

CAR (See AUTOMOBILE)

CEILING

Basement rooms	404.3
Fire-resistance ratings	703.1
Interior surfaces	305.3
Minimum height	404.3
Sleeping rooms	404.3

CHANGE, MODIFY

Application of other codes	102.3
--------------------------------------	-------

CHIMNEY

Exterior structure	304.11
Flue	603.2, 603.3

CLEANING

Access for cleaning	504.2
Disposal of garbage.	308.3
Disposal of rubbish	308.2
Interior and exterior sanitation	308.1
Interior surfaces	305.3
Plumbing facilities, maintained	504.1
Required plumbing facilities.	502
Responsibility of persons.	305.1
Trash containers	308.3.2
Vacant structures and land	301.3

CLEARANCE

Heating facilities.	603.3
Plumbing fixtures	504.2

CLOSING

Streets 109.3
Vacant structures. 108.2

CLOTHES DRYER

Exhaust 403.5

CODE OFFICIAL

Condemnation 108.1
Demolition 110
Duties. 104
Emergency order 109
Enforcement authority 104.1
Failure to comply with demolition order 110.3
Identification. 104.3
Inspections. 104.2
Liability, relief of personal 103.2
Notice of violation 104.5, 107
Notices and orders 107
Official records 104.6
Placarding 108.4
Prosecution 106.3
Removal of placard 108.4.1
Right of entry 104.3
Transfer of ownership 107.6
Vacant structures 108.2

COMBUSTION

Combustion air 304.1.1

COMPONENT SERVICEABILITY

Unsafe conditions. 306.1.1

CONDEMNATION

Closing of vacant structures. 108.2
Failure to comply 110.3
General 108.1
Notices and orders 108.3
Placarding 108.4
Removal of placard 108.4.1

CONFLICT

Violations 106.1

CONNECTION

Sewage system 506.1
Water heating. 505.4
Water system. 505.1

CONSTRUCTION

Existing structures 101.2

CONTAINER

- Garbage 308.3.2
- Rubbish storage. 308.2.1

CONTINUOUS

- Unobstructed egress 702.1

CONTROL

- Rodent control 302.5, 304.5
- Safety controls 603.4
- Weed 302.4

COOLING

- Cooling towers 304.11

CORRIDOR

- Accumulation of rubbish. 308.1
- Light 402.2
- Lighting fixtures 605.3
- Obstructions. 702.1, 702.2
- Ratings maintained 703

D

DAMP, DAMPNES

- Roofs 304.7
- Window, door frames 304.13

DANGEROUS, HAZARDOUS

- Condemnation 108.1
- Demolition. 110
- Electrical hazards 604.3, 604.3.1
- Existing remedies 102.4
- Imminent danger. 202
- Unsafe equipment 108.1.2
- Unsafe structures or premises 108.1.5

DECKS

- Handrails and guardrails. 304.12
- Maintenance 304.2, 304.10

DEMOLITION

- Existing remedies 102.4
- Failure to comply 110.3
- General 110
- Order 110.2
- Salvage materials 110.4

DETECTORS

- Smoke 704

DETERIORATION

- Components of systems 305.1.1
- Definition. 202
- Exterior structure 304.1.1
- Exterior walls 304.6

DIRECT

- Egress 702.1

DISPOSAL

- Disposal of garbage 308.3
- Disposal of rubbish 308.2

DOOR

- Exit doors 702.3
- Fire 703.2
- Hardware 304.15
- Insect screens 304.14
- Interior surfaces 305.3
- Locks 304.15, 702.3
- Maintenance 304.13, 304.15
- Weather tight 304.13
- Window and door frames 304.13

DORMITORY (ROOMING HOUSE, HOTEL, MOTEL)

- Privacy 401.1

DRAIN, DRAINAGE

- Basement hatchways 304.16
- Plumbing connections 506
- Storm drainage 507

DUCT

- Exhaust duct 304.9
- Duct systems 607

DUST

- Process ventilation 403.4

DWELLING

- Cleanliness 305.1, 308.1
- Definition. 202
- Electrical 604.1
- Heating facilities 602
- Required facilities 502

E

EGRESS

- Aisles 702.2

Emergency escape	702.4
General	702.1
Lighting	402.2
Locked doors	702.3
Obstructions prohibited.	702.1
Stairs, porches and railings.	304.10, 305.4, 305.5, 307.1

ELECTRIC, ELECTRICAL EQUIPMENT

Abatement of hazards, fire exposure	604.3
Abatement of hazards, water exposure	604.3.1
Condemnation.	108.1
Electrical equipment	604.3.1.1
Facilities required	604.1
Hazards.	604.3
Installation.	605.1
Lighting fixtures.	605.3
Receptacles	604.3, 605.2
Responsibility	601.2
Service	604.2

ELEVATOR, ESCALATORS, DUMBWAITERS

Condemnation.	108.1
General	606.1
Maintenance	606.1, 606.2

EMERGENCY

Emergency escape openings	702.4
Emergency measures.	109
Emergency orders.	109.1

ENFORCEMENT

Duties and powers	104
Scope	101.2

EQUIPMENT

Alternative.	105.2
Combustion air	603.5
Condemnation.	108.1.2, 108.3
Electrical installation	605.1
Emergency order	109.1
Energy conservation devices	603.6
Installation.	603.1
Interior structure.	305.1
Placarding	108.4, 108.5
Prohibited use	108.5
Responsibility.	601.2
Safety controls	603.4
Scope.	101.2
Scope, mechanical and electrical	601.1
Support, definition	202

Unsafe	108.1.2
Used	105.4

EXHAUST

Clothes dryer	403.5
Exhaust ducts	304.9
Process ventilation.	403.4

EXISTING

Remedies.	102.4
Scope.	101.2
Structural members	304.1.1, 304.4
Structures	101.3

EXTERIOR

Decorative features	304.8
Exterior structure	304
Exterior walls	304.6
Painting	304.2, 304.6
Rodent harborage	302.5, 304.5
Sanitation.	304.1
Scope.	301.1
Stair	304.10
Street numbers	304.3
Unsafe conditions	304.1.1
Weather tight	304.13

F

FAN

Exhaust vents	302.6
-------------------------	-------

FEES, EXPENSES, COST

Closing vacant structures	108.2
Demolition	110.1, 110.3, 110.4
Extermination.	309.2, 309.3, 309.4, 309.5
General	103.1
Relief from personal liability.	103.2

FENCE

Accessory	302.7
Maintenance	304.2

FIRE

Automatic sprinkler systems	704.1.1
Fire-resistance-rated assemblies.	703.1
Fire department connection	704.1.2
Fire protection systems	704
Responsibility, fire safety	701.2
Scope.	101.2
Scope, fire safety	701.1

Smoke alarms 704.2

FLAMMABLE LIQUID

Containers 108.1.2

FLOOR, FLOORING

Area for sleeping purposes 404.4.1
Fire-resistance ratings 703.1
Interior surfaces 305.1, 305.3
Space requirements 404.4.1, 404.6

FOOD PREPARATION

Cooking equipment 403.3
Sanitary condition. 305.1, 404.7
Ventilation 403.4

FOUNDATION

Condemnation 108.1.1
Foundation walls 304.5
Unsafe conditions. 304.1.1, 305.1.1

FRAME

Window and door frames 304.13

G

GAS

Energy conservation devices 603.6
Exhaust vents. 302.6

GLAZING

Materials. 304.13.1

GRADE

Drainage. 302.2, 507

GUARD

Anchorage and maintenance 304.12
Basement windows 304.18.2
Definition 202

H

HABITABLE

Definition 202
Light 402
Minimum ceiling height. 404.3
Minimum room width 404.2
Required plumbing facilities 502
Residential heating facilities. 602.2, 602.3
Space requirements 404.4.1

Ventilation 403

HANDRAILS AND GUARDRAILS

Handrails 304.12, 305.5, 307.1
Stairs and porches 304.10

HARDWARE

Door hardware 304.15, 702.3
Openable windows. 304.13.2

HAZARDOUS (See DANGEROUS, HAZARDOUS) HEAT, HEATING

Energy conservation devices 603.6
Fireplaces 603.1
Heating 603.1
Mechanical equipment 603.1
Required capabilities 602
Residential heating 602.2, 602.3
Supply. 602.3
Water heating facilities 505.4
Water system 505

HEIGHT

Minimum ceiling height 404.3

HOT (See HEAT, HEATING) HOTELS, ROOMING HOUSES AND DORMITORY UNITS, MOTELS

Definition. 202
Locked doors 702.3
Required facilities 502
Toilet rooms 503

HOUSEKEEPING UNIT

Definition. 202

I

IDENTIFICATION

Code official 104.4

INFESTATION

Condemnation 108.1.3
Definition. 202
Insect and rodent 302.5, 304.14, 309.1

INSECTS

Infestation 309.1
Insect screens 304.14
Pest elimination 309

INSPECTIONS

General 104.2
Right of entry 104.3

INSPECTOR

Identification104.4
Inspections104.2
Records104.6

INTENT

Code101.3

INTERIOR

Interior structure 305
Interior surfaces305.3
Means of egress 702
Sanitation305.1
Unsafe conditions 305.1.1

J

JURISDICTION

Title 101.1

K

KITCHEN

Electrical outlets required 605.2
Minimum width 404.2
Prohibited use. 404.4.4
Room lighting 605.3
Water heating facilities 505.4

L

LANDING

Handrails and guards 304.12,
305.5, 306.1
Maintenance 304.10, 305.4

LAUNDRY

Room lighting 605.3
Water-heating facilities 505.4

LAVATORY

Hotels 502.3
Required facilities 502
Rooming houses. 502.2
Sanitary drainage system 506
Water-heating facilities 505.4
Water system 505

LEASE (SELL, RENT)

Heat supplied 602.3

Salvage materials	110.4
Transfer of ownership	107.6

LIEN

Closing of vacant structures	108.2
Demolition	110.3
Failure to comply	110.3

LIGHT, LIGHTING

Common halls and stairways	402.2, 605.3
General	402
Habitable rooms	402.1
Kitchen	605.3
Laundry rooms	605.3
Luminaires	605.3
Other spaces	402.3
Responsibility	401.2
Scope	101.2
Toilet rooms	605.3

LIVING ROOM

Room area	404.4.1
---------------------	---------

LOAD, LOADING

Elevators, escalators and dumbwaiters	606.1
Handrails and guardrails	304.12, 305.5
Live load	304.4, 305.2
Stairs and porches	304.10, 305.2
Structural members	304.4, 305.2

M

MAINTENANCE

Required	102.2
--------------------	-------

MATERIAL

Alternative	105.2
Salvage	110.4
Used	105.4

MEANS OF EGRESS (See EGRESS) MECHANICAL

Installation	603.1
Responsibility	601.2
Scope	601.1
Ventilation, general	403
Ventilation, toilet rooms	403.2

MINIMUM

Ceiling height	404.3
Room area	404.4.1
Room width	404.2

MODIFICATION

Approval. 105.1

MOTEL (See HOTELS) MOTOR VEHICLES

Inoperative 302.8

Painting 302.8

N

NATURAL

Lighting 401.3, 402

Ventilation 401.3, 403

NOTICES AND ORDERS

Appeal 111.1

Form 107.2

Method of service 107.3

Orders 107

Owner, responsible person 107.1

Penalties 107.5

Placarding of structure. 108.4

Transfer of ownership 107.6

Unauthorized tampering 107.4

Vacating structure 108.2

NOXIOUS

Process ventilation. 403.4

Weeds 302.4

NUISANCE

Closing of vacant structures. 108.2

O

OBSTRUCTION

Light 402.1

Right of entry 104.3

OCCUPANCY (See USE) OPENABLE

Locked doors 702.3

Windows. 304.13.2, 403.1

OPERATOR

Definition 202

ORDER (See NOTICE) ORDINANCE, RULE

Applicability 102

Application for appeal. 111.1

OUTLET

Electrical. 605.2

OWNER

Closing of vacant structures. 108.2
Definition 202
Demolition 110
Failure to comply 110.3
Insect and rat control 302.5, 309.2, 309.4
Notice. 107.1, 108.3
Pest elimination 309.2
Placarding of structure 108.4
Responsibility 301.2
Responsibility, fire safety 701.2
Responsibility, light, ventilation 401.2
Responsibility, mechanical and electrical. 601.2
Responsibility, plumbing facilities. 501.2
Right of entry 104.3
Rubbish storage. 308.2.1
Scope. 101.2
Transfer of ownership 107.6

P

PASSAGEWAY

Common hall and stairway. 402.2
Interior surfaces 305.3
Toilet rooms, direct access 503.1

PENALTY

Notices and orders 107.5
Placarding of structure 108.4
Prohibited occupancy. 108.5
Removal of placard 108.4.1
Scope. 101.2
Violations 106.4

PEST ELIMINATION

Condemnation 108.1
Definition. 202
Insect and rodent control 302.5, 304.5, 304.14, 309.1
Pest elimination 309.1
Responsibility of owner. 301.2, 309.2
Responsibility of tenant-occupant. 309.3, 309.4, 309.5

PLACARD, POST

Closing 108.2
Condemnation 108.1
Demolition. 110
Emergency, notice 109.1
Notice to owner. 107.1, 108.3
Placarding of structure 108.4

Prohibited use	108.5
Removal	108.4.1

PLUMBING

Clean and sanitary504.1
Clearance504.2
Connections505.1
Contamination505.2
Employee’s facilities503.3
Fixtures.504.1
Required facilities	502
Responsibility501.2
Sanitary drainage system.	506
Scope501.1
Storm drainage	507
Supply.505.3
Water heating facilities505.4

PORCH

Handrails304.12
Structurally sound.304.10

PORTABLE (TEMPORARY)

Cooking equipment.603.1
----------------------------	--------

PRESSURE

Water supply.505.3
-----------------------	--------

PRIVATE, PRIVACY

Bathtub or shower503.1
Occupancy limitations.404.1
Required plumbing facilities	502
Sewage system506.1
Water closet and lavatory503.1
Water system505.1

PROPERTY, PREMISES

Cleanliness	304.1, 308.1
Condemnation	108
Definition.	202
Demolition.	110
Emergency measures.	109
Exterior areas	302
Failure to comply.	110.3
Grading and drainage	302.2
Pest elimination, multiple occupancy	302.5, 309.4
Pest elimination, single occupancy.	302.5, 309.3
Responsibility	301.2
Scope	301.1
Storm drainage	507
Vacant structures and land	301.3

PROTECTION

- Basement windows 304.17
- Fire protection systems. 704
- Signs, marquees and awnings 304.9

PUBLIC

- Cleanliness 304.1, 305.1
- Egress. 702.1
- Hallway 502.3
- Sewage system. 506.1
- Toilet facilities 502.5, 503
- Vacant structures and land 301.3
- Water system 505

PUBLIC WAY

- Definition. 202

R

RAIN (PREVENTION OF ENTRY INTO BUILDING EXTERIOR ENVELOPE)

- Basement hatchways 304.16
- Exterior walls. 304.6
- Grading and drainage 302.2
- Roofs. 304.7
- Window and door frames 304.13

RECORD

- Official records 104.6

REPAIR

- Application of other codes. 102.3
- Chimneys 304.11
- Demolition 110.1
- Exterior surfaces. 304.1
- Intent 101.3
- Maintenance 102.2
- Signs, marquees and awnings 304.9
- Stairs and porches 304.10
- Weather tight. 304.13
- Workmanship 102.5

REPORTS

- Test reports. 105.3.2

RESIDENTIAL

- Pest elimination. 309
- Residential heating 602.2
- Scope 101.2

RESPONSIBILITY

Pest elimination	309
Fire safety	701.2
Garbage disposal.	308.3
General	301.2
Mechanical and electrical	601.2
Persons	301.1
Placarding of structure.	108.4
Plumbing facilities	501.2
Rubbish storage.	308.2.1
Scope.	101.2, 301.1

REVOKE, REMOVE

Demolition	110
Existing remedies	102.4
Removal of placard	108.4.1
Rubbish removal	308.2.1

RIGHT OF ENTRY

Duties and powers of code official	104.3
Inspections.	104.2

RODENTS

Basement hatchways.	304.16
Condemnation	108
Foundations	304.5
Guards for basement windows	304.17
Harborage	302.5
Insect and rodent control	309.1
Pest elimination	302.5, 309

ROOF

Exterior structure	304.1
Roofs	304.7
Storm drainage	507

ROOM

Bedroom and living room.	404.4
Cooking facilities	403.3
Direct access	503.2
Habitable	402.1
Heating facilities.	602
Light	402
Minimum ceiling heights	404.3
Minimum width.	404.2
Overcrowding.	404.5
Prohibited use	404.4.4
Temperature	602.5
Toilet	503
Ventilation	403

ROOMING HOUSES (See DORMITORY) RUBBISH

Accumulation	308.1
Definition	202
Disposal	308.2
Garbage facilities	308.3.1
Rubbish storage.	308.2.1

S

SAFETY, SAFE

Fire safety requirements	701, 702, 703, 704
Safety controls	603.4

SANITARY

Cleanliness.	304.1, 305.1
Disposal of garbage	308.3
Disposal of rubbish.	308.2
Exterior property areas.	302.1
Exterior structure	304.1
Food preparation	404.7
Furnished by occupant.	302.1
Grease interceptors	506.3
Interior surfaces	305.3
Plumbing fixtures	504.1
Required plumbing facilities	502
Scope.	101.2

SCREENS

Insect screens	304.14
--------------------------	--------

SECURITY

Basement hatchways	304.18.3
Building	304.18
Doors	304.18.1
Vacant structures and land	301.3
Windows.	304.18.2

SELF-CLOSING SCREEN DOORS

Insect screens	304.14
--------------------------	--------

SEPARATION

Fire-resistance ratings	703
Privacy	404.1
Separation of units	404.1

SERVICE

Electrical.	604.2
Method	107.3
Notices and orders	107.1, 108.3
Service on occupant.	108.3

SEWER

General	506.1
Maintenance.	506.2
SHOWER	
Bathtub or shower	502.1
Rooming houses	502.2
Water-heating facilities.	505.4
Water system.	505
SIGN	
Signs, marquees and awnings	304.9
Unauthorized tampering	107.4
SINGLE-FAMILY DWELLING	
Extermination	309
SINK	
Kitchen sink	502.1
Sewage system	506
Water supply.	505.3
SIZE	
Efficiency unit	404.6
Habitable room, light.	402
Habitable room, ventilation	403
Room area	404.4.1
SMOKE ALARMS	
Alarms	704.2
Installation near bathrooms	704.2.1.4
Installation near cooking appliances.	704.2.1.3
Interconnection	704.2.2
Power source	704.2.3
SPACE	
General, light	402
General, ventilation.	403
Occupancy limitations.	404
Privacy	404.1
Scope	401.1
STACK	
Smoke	304.11
STAIRS	
Common halls and stairways, light	402.2
Exit facilities	305.4
Exterior property areas	302.3
Handrails	304.12, 305.5
Lighting	605.3
Stairs and porches	304.10

STANDARD

Referenced102.7

STOP WORK ORDER

Authority112.1
Emergencies.112.3
Failure to comply112.4
Issuance112.2

STORAGE

Food preparation404.7
Garbage storage facilities.308.3
Rubbish storage facilities308.2.1
Sanitation308.1

STRUCTURE

Accessory structures302.7
Closing of vacant structures108.2
Definition.202
Emergency measures.109
General, condemnation.110
General, exterior304.1
General, interior structure305.1
Placarding of structure108.4
Scope301.1
Structural members.304.4, 305.2
Vacant structures and land301.3

SUPPLY

Combustion air603.5
Public water system505.1
Water-heating facilities505.4
Water supply.505.3
Water system505

SURFACE

Exterior surfaces.304.2, 304.6
Interior surfaces305.3

SWIMMING

Enclosure303.2
Safety covers303.2
Swimming pools303.1

T

TEMPERATURE

Nonresidential structures602.4
Residential buildings.602.2
Water-heating facilities505.4

TENANT

Scope 101.2

TEST, TESTING

Agency 105.3.1
Methods 105.3.1
Reports 105.3.2
Required 105.3

TOXIC

Process ventilation 403.4

TRASH

Rubbish and garbage 308

U

UNOBSTRUCTED

Access to public way. 702.1
General, egress 702.1

UNSAFE STRUCTURES AND EQUIPMENT

Abatement methods 108.6
Dangerous structure or premises 108.1.5
Equipment. 108.1.2
Existing remedies 102.4
General, condemnation. 108, 110
General, demolition. 110
Notices and orders. 107, 108.3
Record 108.7
Structures 108.1.1

USE

Application of other codes 102.3
General, demolition 110

UTILITIES

Authority to disconnect 108.2.1

V

VACANT

Abatement methods. 108.6
Authority to disconnect service utilities 108.2.1
Closing of vacant structures 108.2
Emergency measure 109
Method of service 107.3, 108.3
Notice to owner or to
person responsible. 107, 108.3
Placarding of structure. 108.4

Record	108.7
Vacant structures and land	301.3

VAPOR

Exhaust vents	302.6
-------------------------	-------

VEHICLES

Inoperative	302.8
Painting	302.8

VENT

Plumbing hazard	504.3
Exhaust vents	302.6
Flue	603.2

VENTILATION

Clothes dryer exhaust	403.5
Combustion air.	603.5
Definition	202
General, ventilation	403
Habitable rooms.	403.1
Process ventilation.	403.4
Recirculation	403.2, 403.4
Toilet rooms	403.2

VERMIN

Condemnation	108
Insect and rodent control	302.5, 309

VIOLATION

Condemnation	108
Enforcement	106.2
General	106
Notice.	107, 108.3
Separate offenses	106.4
Placarding of structure.	108.4
Prosecution	106.3
Strict liability offense	106.3, 202
Transfer of ownership	107.6

W

WALK

Sidewalks	302.3
---------------------	-------

WALL

Accessory structures	302.7
Exterior surfaces	304.2, 304.6
Exterior walls	304.6
Foundation walls	304.5
General, fire-resistance rating	703.1

Interior surfaces	305.3
Outlets required	605.2
Temperature measurement	602.5

WASTE

Disposal of garbage	308.3
Disposal of rubbish.	308.2
Garbage storage facilities	308.3.1

WATER

Basement hatchways	304.16
Connections	506.1
Contamination	505.2
General, sewage	506
General, storm drainage	507
General, water system	505
Heating.	505.4
Hotels.	502.3
Kitchen sink	502.1
Required facilities.	502
Rooming houses	502.2
Supply	505.3
System	505
Toilet rooms	503
Water-heating facilities.	505.4

WEATHER, CLIMATE

Heating facilities.	602
-----------------------------	-----

WEEDS

Noxious weeds.	302.4
------------------------	-------

WIDTH

Minimum room width	404.2
------------------------------	-------

WINDOW

Emergency escape	702.4
Glazing.	304.13.1
Guards for basement windows.	304.17
Habitable rooms	402.1
Insect screens	304.14
Interior surface	305.3
Light	402
Openable windows	304.13.2
Toilet rooms	403.2
Ventilation.	403
Weather tight	304.13
Window and door frames	304.13

WORKMANSHIP

General	102.5
-------------------	-------