

ADMINISTRATIVE ORDER #2017-3

FIRE PROTECTION SYSTEMS

G. Lock Box / Key Box Requirements

i. Lock Box Installation Requirements

- a.** Lock boxes are to be installed in occupancies and in locations as specified by the currently adopted Fire Alarm Ordinance.

ii. SupraSafe Lock Box Specifications

- b.** When lock boxes are to be installed, they are to be **SupraSafe 2HS/TS surface mounted box** or **SupraSafe 2HSR/TS recessed box**.

iii. Create account for Lock Box purchase at <https://lockbox.shopkidde.com/>

- a.** Fire Department Name for account is **Manheim Township Fire Rescue**
- b.** Choose either SupraSafe 2HS/TS (surface mount) or 2HSR/TS (recessed mount) with tamper switch option.



Supra Safe 2HSR/TS



Supra Safe 2HS/TS

* This Administrative Order replaces Administrative Order #90-5, #99-4, #2006-1, #2007-2, #2011-2, #2013-1 and Standard Design Bulletin #89-3

A handwritten signature in black ink that reads "Andrew S. Bowman".

Issued By:

Andrew S. Bowman, Director of Code Compliance

Effective Date:

May 11, 2018